

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 14406

PRINT OR TYPE ONLY

1. OWNER CHRISTENSEN CONSTRUCTION(DAVIS) ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P.O. Box 1155 2600 Erminia
Verdi, NV 89439 Verdi, NV 89439
 2. LOCATION SW 1/4 SW 1/4 Sec. 15 T. 19N N/S R. 18 E Washoe County
 PERMIT NO. 038-655-05 Beli Ranch Verdi
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil with some smaller bolders		0	2	2
Bolders & gravels cemented with brown sandy clay		2	89	87
Gray clay		89	122	33
Black clay		122	180	58
Gray clay		180	220	40
Soft zone (app 3 GPM)	X	220	222	2
Gray clay		222	235	13
Soft zone (app 2 GPM)	X	235	236	1
Gray clay		236	255	19
Soft zone (app 5 GPM)	X	255	256	1
Gray clay		256	270	14

8. WELL CONSTRUCTION
 Diameter 6 inches Total depth 270 feet
 _____ inches
 _____ inches
 Casing record 270' steel casing installed.
 Weight per foot _____ Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>270</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type cement grout
 Depth of seal 51 feet
 Gravel packed: Yes No
 Gravel packed from 51 feet to 270 feet
 Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 6 around
 From 217 feet to 257 feet
 From _____ feet to _____ feet

Date started 4-24-90, 19____
 Date completed 4-25-90, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 142 feet below land surface
 Flow 10 G.P.M. _____ P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc.
Contractor
 Address P.O. Box 12370, Reno, NV 89510
Contractor
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada contractor's driller's number issued by the Division of Water Resources 908
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed Wayne C. Hedman
By driller performing actual drilling on site or contractor
 Date May 3, 1990