

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 14410

PRINT OR TYPE ONLY

1. OWNER MIKE O'MASSEY ADDRESS AT WELL LOCATION Same
 MAILING ADDRESS 9910 US 395 N
Reno, NV 89506

2. LOCATION SE 1/4 SE 1/4 Sec. 1 T. 20N. N/S R. 18 E. Washoe County
 PERMIT NO. _____ Anderson Acres
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown clay		0	3	3
Tan clay		3	18	15
Rusty brown clay, soft		18	33	25
Yellow-brown clay, med		33	106	73
Yellow-brown with sand streaks, soft	X	106	118	12
Yellow-brown clay wikw harder		118	131	13
Yellow-brown clay with sand streaks, soft	X	131	134	3
Yellow-brown clay harder		134	136	2
Brown clay with sand streaks, soft (est 4GPM)		136	141	5
Brown clay with sand streaks, harder		141	156	15
Sand & gravel (est 17GPM)	X	156	159	3
Brown clay		159	160	on 1

8. WELL CONSTRUCTION
 Diameter 6 inches Total depth 160 feet
 _____ inches
 _____ inches
 Casing record 160' steel casing installed.
 Weight per foot _____ Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>160</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type cement grout
 Depth of seal 51 feet
 Gravel packed: Yes No
 Gravel packed from 51 feet to 160 feet

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 120 feet to 160 feet
 From _____ feet to _____ feet

Date started 4-19-90, 19____
 Date completed 4-20-90, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 52 feet below land surface
 Flow 17 G.P.M. _____ P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc.
 Address P.O. Box 12370, Reno, NV 89510
Contractor
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada contractor's driller's number issued by the Division of Water Resources 908
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 908
 Signed Wayne Drilling, Inc.
By driller performing actual drilling on site or contractor
 Date April 23, 1990