WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 33303
Permit No.
Basin 7-92a

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 14420

1. OWNER MIKE CLARK
MAILING ADDRESS 3230 Wedekin
Sparks, NV 89431

ADDRESS AT WELL LOCATION Carlsbad Road
Reno, NV 89506

2. LOCATION NW ¼ SE ¼ Sec. 24 T. 21N N/S R. 18 E. Washoe County
PERMIT NO. (Issued by Water Resources) 86-213-02 (Parcel No.) Silver Knolls (Subdivision Name)

3. TYPE OF WORK
New Well [X] Recondition [ ]
Deepen [ ] Other [ ]

4. PROPOSED USE
Domestic [X] Irrigation [ ] Test [ ]
Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL
Cable [ ] Rotary [X]
Other [ ] Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown sandy clay		1	36	35
Brown clay		36	68	32
Soft zone (fine sand)		68	71	3
Brown sandy c;lay		71	123	52
Soft zone (NO WATER)		123	136	13
Brown sandy clay		136	161	25
Soft zone (fine sand)	X	161	169	8
Brown clay		169	180	11
Brown clay		180	183	3
Coarse sands& gravels	X	183	196	13
Brown clay		196	200	4

'90 APR 17 A9:17
STATE ENGINEER'S OFFICE

Date started 3-27-90, 19
Date completed 3-28-90, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 6 inches Total depth 200 feet
inches
inches
Casing record 200' steel casing installed.
Weight per foot Thickness .156

Diameter	From	To
6 5/8 inches	0 feet	200 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes [X] No [ ] Type cement grout
Depth of seal 50 feet
Gravel packed: Yes [X] No [ ]
Gravel packed from 50 feet to 200 feet

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 175 feet to 195 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 85 feet below land surface
Flow 35 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne DRillaing, Inc. (Contractor)
Address P.O. Box 12370, Reno, NV 89510 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada contractor's driller's number issued by the Division of Water Resources 908
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date April 2, 1990

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627