

OFFICE USE ONLY
 Log No. 33304
 Permit No. _____
 Basin 685 Sp. Springs V.

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 13960

PRINT OR TYPE ONLY

1. OWNER Chris Foxworthy ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 685 Alamosa 685 Alamosa Dr
Sparks, Nv 89436 Parcel B 18-1-1-6
 2. LOCATION NE 1/4 SW 1/4 Sec. 18 T. 21 N/S R. 21 E Washoe County _____
 PERMIT NO. 076-360-29 - Spanish Springs Valley Ranches Unit # 4
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden		0	1	1
D.G. brown		1	4	3
White granite rock with trace black granite [medium hard]		4	123	119
White granite with trace blue granite rock hard		123	200	77
White & black granite hard		200	238	38
White & black granite medium hard		238	278	40
White & black granite hard		278	316	38
White & black granite medium hard		316	339	23
White & black granite hard		339	380	41
White & black granite broken medium hard		380	480	100
White & black granite medium hard		480	560	80
White & black granite medium hard highly fractured		560	638	78
T.D. 638 ft				

8. 10" - 50" WELL CONSTRUCTION
 Diameter 8 1/2 inches Total depth 638 feet
7 7/8 inches
 Casing record 6 5/8 inch
 Weight per foot 10.78 Thickness .156
 Diameter From To
6 5/8 inches + 2 feet 638 feet
 _____ inches _____ feet _____ feet
 Surface seal: Yes No Type 5 sack well grout
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 638 feet

Perforations:
 Type perforation factory double
 Size perforation 3 32 X 3
 From 598 feet to 618 feet
 From _____ feet to _____ feet

Date started 4/4/90, 19____
 Date completed 4/11/90, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>1909</u>	<u>20</u>	<u>clean and develop.</u>	
<u>17</u>			
<u>17</u>			

9. WATER LEVEL
 Static water level 500 feet below land surface
 Flow 20+ G.P.M. P.S.I. _____
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc
 Address 625 Spice Islands Dr Suite L Sparks, Nv 89431
 Nevada contractor's license number 15291
 issued by the State Contractor's Board
 Nevada contractor's driller's number 1132
 issued by the Division of Water Resources
 Nevada driller's license number issued by the 1509
 Division of Water Resources, the on-site driller
 Signed Roger M. Thrall
 By driller performing actual drilling on site or contractor
 Date 4/13/90

APR 17 1990
 STATE ENGINEER