WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 33326
Permit No.
Basin 4-49

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 13524

1. OWNER ALFRED K. PLANK
MAILING ADDRESS 411 Juniper
Elko, NV 89801

ADDRESS AT WELL LOCATION

2. LOCATION NW ¼ NW ¼ Sec. 7 T. 34 N/S R. 55 E. ELKO County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay & boulders		0	75	75
Red & brown siltstone		75	220	145
Brown siltstone		220	300	80
Brown sandstone		300	360	60
Lt. brown siltstone		360	415	55
Brown/red sand & gravel		415	420	5
Brown/red siltstone		420	460	40
Brown siltstone with gravel streaks		400	520	60
Lt. green shale		520	560	40
Sandstone(grey, green X brown)		560	620	60

RECEIVED 90 MAR 30 A9:48 STATE ENGINEERS OFFICE

Date started March 13, 1990
Date completed March 21, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blow test	20		

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 10 inches Total depth 620 feet
inches
inches
Casing record steel
Weight per foot ..... Thickness 0.156

Diameter	From	To
6 7/8 inches	+1 feet	580 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 620 feet

Perforations:
Type perforation Mill slots
Size perforation 1/8 x 3
From 580 feet to 620 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 400 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °C ..... °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P.O. Box 850 Elko, NV 89801 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada contractor's driller's number issued by the Division of Water Resources 1162
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1120
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 30 MARCH 1990

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627