

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 12979

PRINT OR TYPE ONLY

1. OWNER GARY CARVER ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS Rt. 2 Bell  
ROUND MOUNTAIN, NV. 89045  
 2. LOCATION Sec. 1/4 NW 1/4 Sec. 29 T. 11 N. R. 43 E. Nye County  
 PERMIT NO. 48070 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Gravel	✓	110	120	10
Clay		120	123	3
Gravel		123	128	5
Clay		128	130	2
Gravel		130	134	4
Clay		134	136	2
Gravel		136	142	6
Clay		142	146	4
Gravel		146	153	7
Clay		153	156	3
Gravel	✓	156	160	4
Clay		160	180	20
Gravel	✓	180	190	10
Clay		190	193	3
Gravel	✓	193	205	12
Clay		205	210	5

'90 MAY 10 AND '05  
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION

Diameter 10 inches Total depth 210 feet  
8 inches  
 \_\_\_\_\_ inches

Casing record \_\_\_\_\_  
 Weight per foot 16.79 Thickness .188

Diameter	From	To
<u>10</u> inches	<u>0</u> feet	<u>110</u> feet
<u>8</u> inches	<u>90</u> feet	<u>220</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type \_\_\_\_\_  
 Depth of seal \_\_\_\_\_ feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet

Perforations:  
 Type perforation Milled Slot  
 Size perforation 1/8 x 2 1/2  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 4-16, 1990  
 Date completed 4-19, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

Air Lift

BAILER TEST

G.P.M.	Draw down	feet	hours
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

9. WATER LEVEL  
 Static water level Artesian 209PM feet below land surface  
 Flow 300 G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 60 °F Quality good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Waytek Drilling Co Contractor  
 Address 4662 Maynard Sparks NV Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 24521  
 Nevada contractor's driller's number issued by the Division of Water Resources 1374  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1441  
 Signed Les Weytal  
 By driller performing actual drilling on site or contractor  
 Date 4-23-90