

OFFICE USE ONLY
 Log No. 32177 33371
 Permit No. _____
 Basin A-10B
 NOTICE OF INTENT NO. 14111

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

1. OWNER Walt Tibbles ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 32 Pursel Lane
Yerington, NV 89447
 2. LOCATION W¹/₂ SE ¹/₄ E¹/₂ SW ¹/₄ Sec. 31 T. 13 N/S R. 26 E. Lyon County
 PERMIT NO. 19114 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy Top Soil		0	6	6
Sand & Gravel		6	15	9
Large Granit in Brown Clay		15	25	10
Sand & Large Granit		25	52	27
Brown Clay w/s Rock		52	85	33
Decomposed Granit D.G. and Gravel		85	110	25
Boulders Imbeded in Brown Clay		110	180	70
Large Rocks w/s Boulders in Brown Clay		180	240	60

*2-15-00
 Chico says that
 this is his domestic
 well. He is using
 Well (log 5520) for his
 Permit 61249. CJK*

8. WELL CONSTRUCTION

Diameter 30" to 10 FT inches Total depth 240 feet
20" 10 FT - 240 inches
 _____ inches

Casing record _____
 Weight per foot _____ Thickness 250

Diameter	From	To
<u>24</u> inches	<u>0</u> feet	<u>10</u> feet
<u>12</u> inches	<u>+2</u> feet	<u>80</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type Grout
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 240 feet

Perforations:
 Type perforation Mill Slot
 Size perforation 1/8 x 3 DRB Perf
 From 80 feet to 240 feet
 From _____ feet to _____ feet

Date started April 23, 19 90
 Date completed May 01, 19 90

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	<u>100</u>	<u>196 ft</u>	<u>8 hrs.</u>

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL

Static water level 70 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Humboldt Drilling & Pump Co., Inc.
 Address P.O. Box 592 Wmca., NV 89445
 Nevada contractor's license number issued by the State Contractor's Board 015234
 Nevada contractor's driller's number issued by the Division of Water Resources C-23
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 795
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 5-8-90