

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 15215

PRINT OR TYPE ONLY

1. OWNER ALLEN WILSON ADDRESS AT WELL LOCATION Parcel #1  
MAILING ADDRESS 1066 Mallory Way 3633 Kings Canyon Road  
Carson City, NV 89703 Carson City, NV 89703  
2. LOCATION NW 1/4 NW 1/4 Sec. 24 T. 15 N/S R. 19 E Carson City County  
PERMIT NO. Carson City 20-1 Parcel No. Kings Canyon Subdivision Name  
Issued by Water Resources

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/> Mud <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden - Talus rock, broken, hard to very hard		0	75	75
Fractured granite, cemented, with clay seams		75	189	114
Tight clay seam, grey to brown color		189	193	4
Fractured granite carrying 2 - 3 gpm	x	193	196	3
Clay seam, tight		196	198	2
Fractured granite carrying water	x	198	220	22
T.D.		220		

8. WELL CONSTRUCTION

Diameter 11 3/4 inches Total depth 220 feet

Casing record Steel 6 5/8"

Weight per foot 11.7 Thickness .156

Diameter	From	To
<u>6 5/8"</u> inches	<u>2</u> feet	<u>220</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type Concrete

Depth of seal 103 feet

Gravel packed: Yes  No

Gravel packed from 103 feet to 220 feet

Perforations:

Type perforation Factory mill slot

Size perforation 3/32" x 3"

From 200 feet to 220 feet

From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started May 1990

Date completed June 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Flushed with clean water to remove old drill mud and gravel pack. Blew 12 gpm for 2 hrs from 200 feet			

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL

Static water level 156 feet below land surface

Flow 20 12 - 14 G.P.M. P.S.I.

Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A & H PUMP CO. Contractor

Address Carson City, NV. Contractor

Nevada contractor's license number issued by the State Contractor's Board 23295

Nevada contractor's driller's number issued by the Division of Water Resources \_\_\_\_\_

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674

Signed Joe Butts By driller performing actual drilling on site or contractor

Date June 2/1990