

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 15210

PRINT OR TYPE ONLY

1. OWNER Charles Walker ADDRESS AT WELL LOCATION \_\_\_\_\_  
MAILING ADDRESS \_\_\_\_\_  
San Jose, California 3465 Nye Lane  
Carson City, NV 89704

2. LOCATION SW 1/4 NE 1/4 Sec. 6 T. 16 N/S R. 20 E. Washoe County \_\_\_\_\_  
PERMIT NO. W 65-005031 50-143-01 New Washoe City  
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
New Well  Recondition   
Deepen  Other

4. PROPOSED USE  
Domestic  Irrigation  Test   
Municipal  Industrial  Stock

5. TYPE WELL  
Cable  Rotary   
Other  Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden		0	5	5
White caliche-clay with imbedded gravel		5	30	25
Silty sand		30	80	50
Gravels with fine to sand	x	80	120	40
TD at 120 feet				
Note: 5 foot blank on bottom filled with pea gravel to impede entrance of sand				

8. WELL CONSTRUCTION  
Diameter 11 3/4 inches Total depth 120 feet  
Casing record Steel 6 5/8"  
Weight per foot 11.7 Thickness 1.56

Diameter	From	To
<u>6 5/8</u> inches	<u>2</u> feet	<u>120</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type Concrete  
Depth of seal 65 feet  
Gravel packed: Yes  No   
Gravel packed from 65 feet to 120 feet

Perforations:  
Type perforation Factory Mill Slot  
Size perforation 3" x 3/32"  
From 95 feet to 115 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started May 8, 1990  
Date completed May 9, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Flushed with clean water to remove drill mud and to gravel pack, developed well with air. Blew 22 to 25 gpm from 80' for 2 hours			

9. WATER LEVEL  
Static water level 38 feet below land surface  
Flow 22 - 25 G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name A & H PUMP CO. Contractor  
Address CARSON CITY, NEVADA Contractor  
Nevada contractor's license number 23295 issued by the State Contractor's Board  
Nevada contractor's driller's number \_\_\_\_\_ issued by the Division of Water Resources  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674  
Signed Jerry Burt By driller performing actual drilling on site or contractor  
Date 5/10/90

BAILER TEST

G.P.M.	Draw down	feet	hours