WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 33386
Permit No.
Basin 6-89

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 14927

1. OWNER E.J. CONSTRUCTION CO.
MAILING ADDRESS 3010 Sydney Cir.
Carson City, NV 89701

ADDRESS AT WELL LOCATION Chipmunk
Carson City, NV 89701

2. LOCATION NE ¼ NW ¼ Sec. 32 T. 17N N/S R. 20E E Washoe County
PERMIT NO. (Issued by Water Resources) 50-364-01 (Parcel No.) New Washoe City (Subdivision Name)

3. TYPE OF WORK
New Well XX Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic XX Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary XX
Other ☐ Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fine brown sand		0	14	14
Fine rusty brown sand		14	17	3
Brown clay w/volcanic bolders		17	63	46
Soft zone (NO WATER)		63	64	1
Brown clay w/volcanic bolders		64	90	26
Soft zone(app 3 GPM)	X	90	91	1
Brown volcanic rock		91	105	14
Soft zone	X	105	107	2
Brown volcanic rock		107	115	8
Soft zone	X	115	120	5
BRown volcanic rock		120	133	13
Soft zone	X	133	146	13
Purple volcanic rock		146	150	4

'90 MAY 25 AM 11:17 STATE ENGINEER

Date started 5-18-90, 19
Date completed 5-18-90, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 6 inches Total depth 150 feet
..... inches
..... inches
Casing record 150' steel casing installed.
Weight per foot ..... Thickness .156

Diameter	From	To
6 5/8 inches	0 feet	150 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes XX No ☐ Type cement grout
Depth of seal 51 feet
Gravel packed: Yes XX No ☐
Gravel packed from 51 feet to 150 feet

Perforations:
Type perforation XXX factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 100 feet to 120 feet
From 130 feet to 150 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 32 feet below land surface
Flow 25½ G.P.M. ..... P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370, Reno, NV 89510 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada contractor's driller's number issued by the Division of Water Resources 908
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed Gary C. Fehman (By driller performing actual drilling on site or contractor)
Date May 22, 1990

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627