WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 33424
Permit No. 54309 T
Basin 4-51

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 13691

1. OWNER NEW MOUNT GOLD CO.
MAILING ADDRESS P.O. BOX 667
CARLIN NV 89801

ADDRESS AT WELL LOCATION NEWMOUNT GOLD QUARRY MINE
CARLIN NV

2. LOCATION SW ¼ SW ¼ Sec. 35 T. 37 N/S R. 51 E EUREKA County
PERMIT NO. 54309 - T
Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☒
Municipal ☐ Industrial ☒ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ALTERED SILTSTONE		0		
& CLAY LENSES	NO		300	300
ALTER SILTSTONE	YES	300		
			366	66
SILICIFIED	YES	366		
SILTSTONE			519	153
CARBONIZED	YES	519		
LIME STONE			626	107
SILICIFIED	NO	626		
SILTSTONE			958	332

'90 MAY 15 A9:45
STATE ENGINEER'S OFFICE

Date started MARCH 20, 1990
Date completed APRIL 12, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	250	1	1
	600	4	2
	1300	12	3
	1600	17	4
	2600	25	6
	2500	40 FT	

BAILER TEST
G.P.M. NONE Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter 14 inches Total depth 958 feet
____ inches
____ inches
Casing record 14" FROM +2 FT TO 958 FT
Weight per foot 36.7 Thickness .250

Diameter	From	To
20 inches	0 feet	50 feet
14 inches	50 feet	958 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type BENTONITE & NEAT CEMENT
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from ____ feet to ____ feet

Perforations:
Type perforation ROSCOE MOSS LOUVERS
Size perforation .45
From 230 feet to 917 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 37 feet below land surface
Flow ____ G.P.M. ____ P.S.I.
Water temperature 80 °F Quality FAIR

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HOLMAN DRILLING CORP
Contractor
Address 1534 E. 9TH AVE SPOKANE WA 99202
Contractor
Nevada contractor's license number issued by the State Contractor's Board C028303
Nevada contractor's driller's number issued by the Division of Water Resources 1599
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1599
Signed Gerald E. Holman
By driller performing actual drilling on site or contractor
Date MAY 10 1990

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627