


Log No. **33451**

Permit No. _____

Basin _____



WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. **2706**

PRINT OR TYPE ONLY

1. OWNER Dorothea Row ADDRESS AT WELL LOCATION same
 MAILING ADDRESS P.O. Box 414 Caliente
Nevada 89008
 2. LOCATION S/E 1/4 N/E 1/4 Sec. 1 T. 4 R. 67 E. Lincoln County
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	10	10
Hard Rock		10	55	45
Fractured Rock		55	62	7
Cemented Gravel		62	140	78
Rock Volcanic		140	170	30
Fractured Rock		170	174	4
Volcanic Rock		174	260	86
Fractured		260	275	15
Fractured same quartz		275	292	17
Hard Rock volcanic		292	310	18

TD 310'

RECEIVED

APR 10 1990

Div. of Water Resources
 Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
 Diameter 7 7/8 inches Total depth 310 feet
7 7/8 inches
 _____ inches
 Casing record 0
 Weight per foot 0 Thickness 0

Diameter	From	To
<u>0</u> inches	<u>0</u> feet	<u>0</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type _____
 Depth of seal _____ feet
 Gravel packed: Yes No
 Gravel packed from 0 feet to _____ feet
 Perforations:
 Type perforation 0
 Size perforation _____
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 4-15-90 _____ 19_____
 Date completed 4-31-90 _____ 19_____
 Div. of Water Resources
 Branch Office - Las Vegas, NV

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>0</u>			
<u>NO water Dry hole</u>			

BAILER TEST

G.P.M.	Draw down	feet	hours
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

9. WATER LEVEL
 Static water level 0 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Davis Drilling - pumps Contractor
 Address P.O. Box 54 Hiko NV, 89012 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 0028266
 Nevada contractor's driller's number issued by the Division of Water Resources _____
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191
 Signed Mike J. Davis
 By driller performing actual drilling on site or contractor
 Date 9-5-90

