WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 33471
Permit No.
Basin 162

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 3689

1. OWNER RICHARD THOMPSON
MAILING ADDRESS
ADDRESS AT WELL LOCATION

2. LOCATION NE ¼ NE ¼ Sec. 32 T. 19 S N/S R. 53 E NYE County
PERMIT NO. (Issued by Water Resources) LOT 25 (Parcel No.) UNIT 7 BLOCK 1 RANCHO DEL-SOL (Subdivision Name)

3. TYPE OF WORK: New Well ☑ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☑ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☑ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	6	6
CALICHIE		6	7	1
CLAY		7	18	11
CALICHIE		18	19	1
CLAY		19	33	14
CALICHIE		33	35	2
CLAY		35	42	7
CALICHIE		42	45	3
CLAY		45	57	12
CALICHIE	WB	57	62	5
CLAY		62	66	4
CALICHIE	WB	66	67	1
CLAY		67	83	16
CALICHIE	WB	83	86	3
CLAY		86	90	4
CALICHIE	WB	90	93	3
CLAY		93	98	5
CALICHIE	WB	98	99	1
CLAY		99	116	17
CALICHIE	WB	116	118	2
CLAY		118	120	2
CALICHIE	WB	120	122	2
CLAY		122	131	9
CALICHIE	WB	131	133	2
CLAY		133	140	7

Date started 3-16, 1990
Date completed 3-21, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

RECEIVED
APR 04 1990
Div. of Water Resources
Branch Office - Las Vegas, NV

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12¼ inches Total depth 140 feet
inches
inches
Casing record 140' 8 5/8 OD
Weight per foot 14.11 Thickness .156

Diameter	From	To
8 5/8 inches	0 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type CONCRETE
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 140 feet to 50 feet

Perforations:
Type perforation FACTORY SAW CUT
Size perforation ⅛ INCH BY 3 INCH
From 140 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 37 feet below land surface
Flow G.P.M. P.S.I.
Water temperature COOL °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name S+H DRILLING (Contractor)
Address HCR 65 BOX 80358 PAHRUMP NV 89041 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22059
Nevada contractor's driller's number issued by the Division of Water Resources 1426
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 4-2-90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627