



PRINT OR TYPE ONLY

WELL DRILLER'S REPORT  
 Please complete this form in its entirety

NOTICE OF INTENT NO. 7043

1. OWNER CALVIN MCKINLEY ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION NE 1/4 SE 1/4 Sec. 32 T. 19S N/S R. 53 E NYE County  
 PERMIT NO. lot 13 Parcel No. Block 2 Unit 7 Rancho Del-sol Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Rotary  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay		0'	8'	8'
calichie		8'	9'	1'
clay		9'	18'	9'
calichie		18'	19'	1'
clay		19'	43'	24'
calichie		43'	46'	3'
clay		46'	52'	6'
calichie	WB	52'	55'	3'
clay		55'	63'	8'
calichie	WB	63'	65'	2'
clay		65'	72'	7'
calichie	WB	72'	74'	2'
clay		74'	82'	8'
calichie	WB	82'	86'	4'
clay		86'	97'	11'
calichie	WB	97'	98'	1'
clay		98'	123'	25'
calichie	WB	123'	126'	3'
clay		126'	132'	6'
calichie	WB	132'	134'	2'
clay		134'	138'	4'
calichie	WB	138'	140'	2'

8. WELL CONSTRUCTION  
 Diameter 12 1/4 inches Total depth 140' feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record 140' x 8 5/8"  
 Weight per foot 14.11 Thickness 1.56  

Diameter	From	To
<u>8 5/8</u> inches	<u>0</u> feet	<u>140</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type concrete  
 Depth of seal 50' feet  
 Gravel packed: Yes  No   
 Gravel packed from 140 feet to 50 feet  
 Perforations:  
 Type perforation factory sawcut  
 Size perforation 1/8" x 3"  
 From 140 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 5-30, 1990  
 Date completed 6-4, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

Div. of Water Resources  
 Baiter Test Office - Las Vegas, NV

G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 37 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COOL °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name S & H DRILLING  
 Address HCR 65 box 80358 PAHRUMP NV  
 Nevada contractor's license number issued by the State Contractor's Board 22059  
 Nevada contractor's driller's number issued by the Division of Water Resources 1426  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573  
 Signed Donna Brown  
 Date 6-7-90

RECEIVED  
 JUN 13 1990

