WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 33487
Permit No.
Basin 162

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 3707

1. OWNER Bill Brown
MAILING ADDRESS
ADDRESS AT WELL LOCATION

2. LOCATION SE ¼ NW ¼ Sec. 34 T. 19S N/S R. 53 E. NYE County
PERMIT NO. (Issued by Water Resources) LOT: 2 (Parcel No.) Block B W.M. Moore Survey (Subdivision Name)

3. TYPE OF WORK: New Well ☑ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☑ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☑ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND & GRAVEL		0	9	9
CALICHIE		9	10	1
SAND		10	16	6
CLAY		16	22	6
CALICHIE		22	26	4
CLAY		26	36	10
CALICHIE		36	37	1
SAND - GRAVEL		37	44	7
CALICHIE		44	47	3
SAND & GRAVEL		47	56	9
CALICHIE		56	60	4
CLAY & GRAVEL		60	100	40
CALICHIE	WB	100	105	5
CLAY & GRAVEL		105	116	11
ROCK & GRAVEL		116	119	3
CLAY & GRAVEL		119	130	11
SAND & GRAVEL	WB	130	160	30

Date started 4-10, 1990
Date completed 4-13, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

RECEIVED
APR 23 1990
Div. of Water Resources
Branch Office - Las Vegas, NV

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12¼ inches Total depth 160 feet
inches
inches
Casing record 160' 8 5/8 OD
Weight per foot 14.11 Thickness .156

Diameter	From	To
8 5/8 inches	0 feet	160 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type CONCRETE
Depth of seal 50' feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 160 feet to 50 feet

Perforations:
Type perforation FACTORY SAW CUT
Size perforation ¼ INCH BY 3 INCH
From 160 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 80' feet below land surface
Flow G.P.M. P.S.I.
Water temperature Cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name S & H Drilling (Contractor)
Address HCR 65 Box 80358 Pahrump NV. 89041 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22059
Nevada contractor's driller's number issued by the Division of Water Resources 1426
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 2

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627