


OFFICE USE ONLY  
 Log No. 33504  
 Permit No. \_\_\_\_\_  
 Basin 212



**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety

NOTICE OF INTENT NO. 5022

PRINT OR TYPE ONLY

1. OWNER Erad Garrett ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 1108 Stoney Beach St. 6420 Tropical Parkway, L. V.  
Las Vegas, Nevada 89110  
 2. LOCATION SE  $\frac{1}{4}$  NW  $\frac{1}{4}$  Sec. 26 T. 19 N/S R. 60 E. Clark County  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Other

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil <u>2</u>		0	3	3
caliche		3	5	2
white graveley clay		5	30	25
white clay		30	55	25
brown sandy clay		55	75	20
gravel		75	85	10
brown graveley clay	x	85	268	183
gravel	x	268	275	7
brown clay		275	368	93
gravel	xxx	368	400	32

8. WELL CONSTRUCTION  
 Diameter 10 inches Total depth 400 feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record 8 5/8 inch to 400 ft.  
 Weight per foot \_\_\_\_\_ Thickness .156  

Diameter	From	To
12" hole inches	0	50
10" hole inches	50	400
_____ inches	_____	_____
8 5/8 inches casing	0	400
_____ inches	_____	_____
_____ inches	_____	_____

 Surface seal: Yes  No  Type cement  
 Depth of seal 50 ft. feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Perforations:  
 Type perforation torch cut  
 Size perforation 3/16" X 10"  
 From 200 feet to 400 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

**RECEIVED**  
 APR 13 1990  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started 1-29-90, 19\_\_\_\_  
 Date completed 2-14-90, 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

Biled 40 G.P.M. from 205 ft.

9. WATER LEVEL  
 Static water level 124 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name S. R. McKinney & Sons, Inc.  
 Contractor  
 Address 1042 S. Main St. Las Vegas, Nevada  
 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 2065  
 Nevada contractor's driller's number issued by the Division of Water Resources 15  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 270  
 Signed [Signature]  
 By driller performing actual drilling on site or Contractor  
 Date 3-14-90



BAILER TEST

G.P.M.	Draw down	feet	hours