WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 33565
Permit No.
Basin 162

in Book

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 3790

1. OWNER JACK STEIN
MAILING ADDRESS
ADDRESS AT WELL LOCATION

2. LOCATION SW ¼ SW ¼ Sec. 18 T. 20S N/S R. 53 E. NYE County
PERMIT NO. (Issued by Water Resources) 140 (Parcel No.) UNIT 5 CHARLESTON PARK (Subdivision Name)

3. TYPE OF WORK: New Well ☑ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☑ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☑ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	9	9
CALICHIE		9	11	2
CLAY		11	43	32
CALICHIE		43	45	2
CLAY		45	56	11
CALICHIE	WB	56	59	3
CLAY		59	65	6
CALICHIE	WB	65	67	2
CLAY		67	78	11
CALICHIE	WB	78	80	2
CLAY		80	90	10
CALICHIE	WB	90	93	3
CLAY		93	101	8
CALICHIE	WB	101	104	3
CLAY		104	112	8
CALICHIE	WB	112	113	1
CLAY		113	129	16
CALICHIE	WB	129	133	4
CLAY		133	140	7

RECEIVED
FEB 8 1990
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 1-30, 1990
Date completed 2-3, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12¼ inches Total depth 140 feet
inches
inches
Casing record 140 8 5/8 O.D.
Weight per foot 14.11 Thickness .156

Diameter	From	To
8 5/8 inches	0 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type CONCRETE
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 140 feet to 50 feet

Perforations:
Type perforation FACTORY SAW CUT
Size perforation ⅛ INCH BY 3 INCH
From 140 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 39 feet below land surface
Flow G.P.M. P.S.I.
Water temperature COOL °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name S & H Drilling (Contractor)
Address HCR 65 BOX 70906 PAHRUMP NV 89041 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22059
Nevada contractor's driller's number issued by the Division of Water Resources 1426
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
Signed Donna Brown (By driller performing actual drilling on site or contractor)
Date 2-5-90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627