

Log No. 33579  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 3879

PRINT OR TYPE ONLY

1. OWNER J. SANDERS ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION NE 1/4 SE 1/4 Sec. 32 T. 20S N/S R. 53 E NYE County \_\_\_\_\_  
 PERMIT NO. lot 21 Block 2 Unit 7 Rancho Del Sol  
 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
clay		0'	10'	10'
caliche		10'	11'	1'
clay		11'	41'	30'
caliche		41'	43'	2'
clay		43'	56'	13'
caliche	WB	56'	57'	1'
clay		57'	62'	5'
caliche	WB	62'	64'	2'
clay		64'	74'	10'
caliche	WB	74'	76'	2'
clay		76'	88'	12'
caliche	WB	88'	90'	2'
clay		90'	96'	6'
caliche	WB	96'	97'	1'
clay		97'	114'	17'
caliche	WB	114'	116'	2'
clay		116'	120'	4'
caliche	WB	120'	122'	2'
clay		122'	126'	4'
caliche	WB	126'	128'	2'
clay		128'	133'	5'
caliche	WB	133'	136'	3'
clay		136'	139'	3'
caliche	WB	139'	140'	1'

8. WELL CONSTRUCTION  
 Diameter 12 1/2 inches Total depth 140' feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record 140' x 8 5/8"  
 Weight per foot 14.11 Thickness .156  

Diameter	From	To
<u>8 5/8</u> inches	<u>0</u> feet	<u>140</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type concrete  
 Depth of seal 50' feet  
 Gravel packed: Yes  No   
 Gravel packed from 140 feet to 50 feet  
 Perforations:  
 Type perforation factory sawcut  
 Size perforation 1/8" x 3"  
 From 140' feet to 100 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 4-20, 1990  
 Date completed 4-25, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>RECEIVED</u>			

Div. of Water Resources  
 Branch Office - Las Vegas, NV  
 BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 38 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name S&H DRILLING  
 Address HCR 65 BOX 80358 PAHRUMP, NV 89041  
 Nevada contractor's license number issued by the State Contractor's Board 22059  
 Nevada contractor's driller's number issued by the Division of Water Resources 1426  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573  
 Signed Donnie Brown  
 By driller performing actual drilling on site or contractor  
 Date 5-9-90