

OFFICE USE ONLY  
 Log No. 33601  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_  
 NOTICE OF INTENT NO. 3786

PRINT OR TYPE ONLY

WELL DRILLER'S REPORT

Please complete this form in its entirety

1. OWNER DICK STEWART ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION SE 1/4 SW 1/4 Sec 1 T 21 S N 53 E County NYE  
 PERMIT NO. ACT 189 Parcel No. MANKO Subdivision Name SUB DIVISION  
 Issued by Water Resources \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	18	18
CALICHE		18	20	2
CLAY		20	37	17
CALICHE		37	39	2
CLAY		39	43	4
CALICHE	TC	43	55	12
CLAY		55	65	10
CALICHE	WB	65	66	1
CLAY		66	71	5
CALICHE	WB	71	74	3
CLAY		74	89	15
CALICHE	WB	89	91	2
CLAY		91	98	7
LIMESTONE	WB	98	122	24
CLAY		122	136	14
LIMESTONE	WB	136	140	4

8. WELL CONSTRUCTION  
 Diameter 12 1/4 inches Total depth 140 feet  
 Casing record 140' 8 5/8" O.D.  
 Weight per foot 14.11 15.6 Thickness 15.6  

Diameter	From	To
<u>8 5/8</u> inches	<u>0</u> feet	<u>140</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type CONCRETE  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 140 feet to 50 feet  
 Perforations:  
 Type perforation FACTORY SAW CUT  
 Size perforation 5 INCH BY 3 INCH  
 From 140 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

RECEIVED  
 JAN 23 1997  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started 1-9, 1990  
 Date completed 1-15, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 49 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 60.0 °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name S+H DRILLING Contractor  
 Address HCR 65 BOX 70406 Pahrump NV Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 22059  
 Nevada contractor's driller's number issued by the Division of Water Resources 1426  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573  
 Signed Wanda Brown  
 By driller performing actual drilling on site or contractor  
 Date 1-18-1990