



WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

1. OWNER CHUCK KING ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____
 2. LOCATION NE 1/4 SW 1/4 Sec. 2 T 21S N/S R. 53 E NYE County
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
		0'	4'	4'
shie		4'	5'	1'
		5'	12'	7'
shie		12'	13'	1'
clay		13'	17'	4'
caliche		17'	19'	2'
clay		19'	24'	5'
caliche		24'	27'	3'
clay		27'	55'	28'
caliche		55'	57'	2'
clay		57'	66'	9'
caliche		66'	67'	1'
clay		67'	78'	11'
caliche	WB	78'	81'	3'
clay		81'	106'	25'
caliche	WB	106'	107'	1'
clay		107'	113'	6'
caliche	WB	113'	115'	2'
clay		115'	122'	7'
caliche	WB	122'	124'	2'
clay		124'	131'	7'
caliche	WB	131'	135'	4'
clay		135'	140'	5'

RECEIVED
 JUN 13 1990
 Div. of Water Resources
 Branch Office Las Vegas, NV

8. WELL CONSTRUCTION
 Diameter 12 1/4 inches Total depth 140 feet
 _____ inches
 _____ inches
 Casing record 140' X 8 5/8"
 Weight per foot 14.11 Thickness .156
 _____ diameter From _____ To _____
8 5/8 inches _____ 0 feet _____ 140 feet
 _____ inches _____ feet _____ feet
 Surface seal: Yes No Type concrete
 Depth of seal 50' feet
 Gravel packed: Yes No
 Gravel packed from 140 feet to 50 feet
 Perforations:
 Type perforation factory sawcut
 Size perforation 1 7/8" X 3"
 From 140 feet to 120 feet
 From _____ feet to _____ feet

Date started 5-21 1990
 Date completed 5-25 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 52 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name S&H DRILLING Contractor
 Address HCR 65 box 80358 Pahrump, NV 89041 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 22059
 Nevada contractor's driller's number issued by the Division of Water Resources 1426
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
 Signed Dennis Brown
 By driller performing actual drilling on site or contractor
 Date 5-25-90

