WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 33614
Permit No.
Basin 162

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 3698

1. OWNER LEO TRAVERS
MAILING ADDRESS
ADDRESS AT WELL LOCATION

2. LOCATION NW ¼ NE ¼ Sec. 11 T. 21 S N/S R. 53 E. NYE County
PERMIT NO. (Issued by Water Resources) LOT - 12 (Parcel No.) BLOCK 6 JOYCELYNN ESTATES (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	7	7
CALICHIE		7	8	1
CLAY		8	24	16
CALICHIE		24	25	1
CLAY		25	52	27
CALICHIE	WB	52	55	3
CLAY		55	67	12
CALICHIE	W.B.	67	69	2
CLAY		69	84	15
CALICHIE	WB	84	88	4
CLAY		88	106	18
CALICHIE	W.B.	106	108	2
CLAY		108	118	10
CALICHIE	W.B	118	122	4
CLAY		122	137	15
CALICHIE	W.B	137	140	3

RECEIVED
APR 23 1990
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 4-5, 1990
Date completed 4-9, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12¼ inches Total depth 140 feet
inches
inches
Casing record 140 8 5/8 OD
Weight per foot 14.11 Thickness .156

Diameter	From	To
8 5/8 inches	0 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type CONCRETE
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 140 feet to 50 feet

Perforations:
Type perforation FACTORY SAW CUT
Size perforation 1/8 INCH by 3 INCH
From 140 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 47 feet below land surface
Flow G.P.M. P.S.I.
Water temperature COOL °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name S+H DRILLING (Contractor)
Address HCR 65 BOX 80358 PAHRUMP NV. 89041 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22059
Nevada contractor's driller's number issued by the Division of Water Resources 1426
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
Signed (By driller performing actual drilling on site or contractor)
Date 4-17-90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627