

OFFICE USE ONLY
 Log No. 33626
 Permit No. _____
 Basin _____
 NOTICE OF INTENT NO. 3703

WELL DRILLER'S REPORT
 Please complete this form in its entirety

1. OWNER KEN HEPTNER ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____
 2. LOCATION SW 1/4 NW 1/4 Sec 14 T 21S N/S R 53 E NVE County _____
 PERMIT NO. _____ Parcel No. _____ Subdivision Name UNIT 1 BLOCK 7 MESA OSTA

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	1	1
CALICHE		1	2	1
CLAY		2	7	5
CALICHE		7	12	5
CLAY		12	28	16
CALICHE		28	29	1
CLAY		29	40	11
CALICHE		40	45	5
CLAY		45	54	9
CALICHE	WB	54	59	5
CLAY		59	62	3
CALICHE	W.B.	62	63	1
CLAY		63	74	11
CALICHE	WB	74	77	3
CLAY		77	110	33
CALICHE	W.B.	110	112	2
CLAY		112	118	6
CALICHE	W.B.	118	119	1
CLAY		119	122	3
CALICHE	W.B.	122	127	5
CLAY		127	133	6
CALICHE	W.B.	133	135	2
CLAY		135	139	4
CALICHE	W.B.	139	140	1

8. WELL CONSTRUCTION
 Diameter 12 1/4 inches Total depth 140 feet
 _____ inches
 _____ inches
 Casing record 140' 8 5/8
 Weight per foot 14.11 Thickness .156

Diameter	From	To
<u>8 5/8</u> inches	<u>0</u> feet	<u>140</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type CONCRETE
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 140 feet to 50 feet
 Perforations:
 Type perforation FACTORY SAW CUT
 Size perforation 1/8 INCH BY 3/8 INCH
 From 140 feet to 120 feet
 From _____ feet to _____ feet

Date started 4-9, 1990
 Date completed 4-13, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

Div. of Water Resources
 Branch Office - Las Vegas, NV
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 46 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name S+H Drilling Contractor
 Address HCR 65 BOX 80358 PAHRUMP NV 89041 Contractor
 Nevada contractor's license number 22059 issued by the State Contractor's Board
 Nevada contractor's driller's number 1426 issued by the Division of Water Resources
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
 Signed Annex Brown By driller performing actual drilling on site or contractor
 Date 4-17-90

RECEIVED
 APR 23 1990

