


Log No. **33634**

Permit No.

Basin. **16a**



**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. **3885**

1. OWNER **RON TALMADGE** ADDRESS AT WELL LOCATION **PIUTE**  
 MAILING ADDRESS.....

2. LOCATION **SE 1/4 NE 1/4 Sec 20 T 21S N/S R 54 E NYE County**  
 PERMIT NO. **lot 186** GREEN SADDLE RANCH  
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay		0'	12'	12'
calichie		12'	13'	1'
clay		13'	17'	4'
calichie		17'	18'	1'
clay		18'	25'	7'
Gravel		25'	33'	8'
clay		33'	38'	5'
calichie		38'	45'	7'
gravel & rock		45'	51'	6'
clay		51'	56'	5'
gravel & calichie		56'	58'	2'
calichie		58'	65'	7'
clay		65'	70'	5'
calichie		70'	73'	3'
clay		73'	76'	3'
gravel		76'	79'	3'
clay		79'	81'	2'
calichie		81'	84'	3'
gravel		84'	89'	5'
clay		89'	96'	7'
calichie	WB	96'	97'	1'
clay		97'	99'	2'
calichie	WB	99'	105'	6'
clay		105'	115'	10'
calichie	WB	115'	117'	2'
clay		117'	122'	5'
gravel	WB	122'	140'	18'

8. WELL CONSTRUCTION  
 Diameter **12 1/2** inches Total depth **140'** feet  
 inches  
 inches  
 Casing record **140' x 8 5/8"**  
 Weight per foot **14.11** Thickness **.156**  

Diameter	From	To
<b>8 5/8</b> inches	<b>0</b> feet	<b>140</b> feet
.....	.....	.....
.....	.....	.....
.....	.....	.....
.....	.....	.....
.....	.....	.....
.....	.....	.....
.....	.....	.....
.....	.....	.....
.....	.....	.....

 Surface seal: Yes  No  Type **concrete**  
 Depth of seal **50'** feet  
 Gravel packed: Yes  No   
 Gravel packed from **140'** feet to **120'** feet  
 Perforations:  
 Type perforation **factory sawcut**  
 Size perforation **1/8" x 3"**  
 From **140** feet to **120** feet  
 From ..... feet to ..... feet

Date started **4-24-90**  
 Date completed **4-30-90**

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
 G.P.M. ..... Draw down ..... feet ..... hours  
 G.P.M. ..... Draw down ..... feet ..... hours  
 G.P.M. ..... Draw down ..... feet ..... hours

9. WATER LEVEL  
 Static water level **70** feet below land surface  
 Flow ..... G.P.M. .... P.S.I.  
 Water temperature **cool** °F Quality .....

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **S&H DRILLING** Contractor  
 Address **HCR 65 box 80358 PAHRUMP, NV 89041** Contractor  
 Nevada contractor's license number **22059** issued by the State Contractor's Board  
 Nevada contractor's driller's number **1426** issued by the Division of Water Resources  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1573**  
 Signed **James Brown**  
 By driller performing actual drilling on site or contractor  
 Date **5-9-90**

