

Log No. 33691
 Permit No. _____
 Basin 1103

WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 5544

PRINT OR TYPE ONLY

1. OWNER RICH BALE ADDRESS AT WELL LOCATION West of Mormon Church, Sandy Valley Road.
 MAILING ADDRESS Box 409, HCR 31

2. LOCATION SE 1/4 NW 1/4 Sec. A T. 25 N/S R. 57 E CLARK County

PERMIT NO. 620.510.01A Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK: New Well Recondition Deepen Other
 4. PROPOSED USE: Domestic Irrigation Industrial Municipal Test Stock
 5. TYPE WELL: Cable Rotary Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
ALLUVIUM		0	49	49
BROWN CLAY		49	74	25
SAND & Rock	74	74	78	4
SANDY CLAY		78	84	6
BROWN CLAY		84	88	4
SAND & Rock	Wtr	88	98	10
BROWN CLAY		98	118	20
White SANDY CLAY		118	132	14
CALICHE	WTR	132	140	8

8. WELL CONSTRUCTION
 Diameter hole 14 inches Total depth 140 feet
 Casing record STEEL
 Weight per foot 12.5 Thickness 1.56
 Diameter 8 7/8 inches From 0 feet To 140 feet
 Surface seal: Yes No Type CEMENT
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 140 feet
 Perforations:
 Type perforation FLAME CUT
 Size perforation 3/8 x 4, 4 Rows @ 16' ca
 From 100 feet to 140 feet

RECEIVED
 MAR 10 1990
 Div. of Water Resources
 Branch Office - Las Vegas, NV

9. WATER LEVEL
 Static water level 68 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature 72 ° F. Quality Good

Date started 2-16 1990
 Date completed 3-9 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name R.C.B. INC Contractor
 Address 1701 WHEATSTN BLVD LAS VEGAS NV 89102 Contractor
 Nevada contractor's license number 020301
 Nevada contractor's drillers number 1352
 Nevada driller's license number 1352 Actual Driller
 Signed Robert Spurlock Contractor
 Date 3-9-90

BAILER TEST
 G.P.M. 40 Draw down 6 feet 2 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours