

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 15565

PRINT OR TYPE ONLY

1. OWNER Anthony Daly ADDRESS AT WELL LOCATION 21305 Highland Rd  
 MAILING ADDRESS 5316 Chocolate Dr 21305 Highland Rd  
Sun Valley, Nv 89433 Lot 30 Block U  
 LOCATION NW 1/4 NW 1/4 Sec. 7 T 17 N/S R. 21 E Storey County Virginia City Highlands  
 PERMIT NO. 003-191-03 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other  Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Tan clay		0	18	18
Light tan clay		18	21	3
Reddish tan clay		21	42	21
Green gray clay		42	138	96
Soft blue gray rock	[2 GPM] [140']	138	161	23
Dark green rock medium hard fractured	X	161	196	35
T.D. 196 ft				

This well took twice the calculated amount of pea gravel.

8. 10" - 58" WELL CONSTRUCTION

Diameter 8 1/2 inches Total depth 196 feet

Casing record 6 5/8 inch  
 Weight per foot 10.78 Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>+ 4</u> feet	<u>196</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type grout  
 Depth of seal 54 feet  
 Gravel packed: Yes  No   
 Gravel packed from 54 feet to 196 feet

Perforations:  
 Type perforation factory  
 Size perforation 3/32 X 3  
 From 176 feet to 196 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 5/5/90, 19\_\_\_\_  
 Date completed 5/6/90, 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air for 1 hour to clean and develop.			

BAILER TEST

G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL

Static water level 90 feet below land surface  
 Flow 20+ G.P.M. P.S.I. \_\_\_\_\_  
 Water temperature cool °F Quality irony

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Aqua Drilling & Well Service, Inc  
 Address 625 Spice Islands Dr Suite L Sparks, Nv 89431  
 Nevada contractor's license number issued by the State Contractor's Board 15291  
 Nevada contractor's driller's number issued by the Division of Water Resources 1132  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1132  
 Signed Roger M. Thrall  
 By driller performing actual drilling on site or contractor  
 Date Roger M. Thrall 5/7/90