

OFFICE USE ONLY
 Log No. 33800
 Permit No. I
 Basin 105 Carson V.
 NOTICE OF INTENT NO. 11490

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

1. OWNER JOBS PEAK CONSTRUCTION ADDRESS AT WELL LOCATION 1357 Creek Drive
 MAILING ADDRESS 3470 Vista Grande GARDNERVILLE, NV 89410
CARSON CITY, NV 89705
 2. LOCATION SW $\frac{1}{4}$ NE $\frac{1}{4}$ Sec. 5 T. 12 N/S R. 21 E. DOUGLAS County
 PERMIT NO. NONE 35-311-05 PINE NUT HILLS RANCH
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden with up to 6" cobbles		0	6	6
Gravel and sand with heavy clay		6	88	82
Tight clay with fine sand		88	97	9
Gravel with sand and clay lenses		97	155	58
Clay, hard, yellow-brown coloration		155	162	7
Gravel with medium to course sand carrying water	xxx	162	185	23
T.D. 185 ft				

8. WELL CONSTRUCTION
 Diameter 11 3/4 inches Total depth 185 feet
 Casing record steel
 Weight per foot 11.7 Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>2 1/2</u> feet	<u>185</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type Concrete
 Depth of seal 55 feet
 Gravel packed: Yes No
 Gravel packed from 55 feet to 185 feet
 Perforations:
 Type perforation Factory Mill Slot
 Size perforation 3/32" x 3"
 From 165 feet to 185 feet
 From _____ feet to _____ feet

Date started June 27 1990
 Date completed June 29 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Flushed with clear water to gravel pack and develop. Developed well with 450 - 250 air			
Blow well for 2 hours from 120 to 160 feet.			
Well capable of 20 to 22 gpm from 160 ft.			

BAILER TEST

G.P.M.	Draw down	feet	hours
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

9. WATER LEVEL
 Static water level 38 feet below land surface
 Flow 20 - 22 G.P.M. P.S.I.
 Water temperature Cool °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A & H PUMP CO. Contractor
 Address CARSON CITY, NV 89701 Contractor
 Nevada contractor's license number 23295 issued by the State Contractor's Board
 Nevada contractor's driller's number _____ issued by the Division of Water Resources
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date July 2, 1990