

OFFICE USE ONLY
 Log No. 33820
 Permit No. _____
 Basin G-83 Tracy Segment
 NOTICE OF INTENT NO. 15574

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

1. OWNER Danny & Yvonne Sherman ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 21585 Sarazac # 130 21585 Sarazac
Reno, Nv 89511 Lot 235 Block M
 2. LOCATION NW 1/4 SE 1/4 Sec. 32 T. 18 N/S R. 21 E. Storey County _____
 PERMIT NO. 03-081-51 Virginia City Highlands
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|--------------------------------|--------------|------|-----|------------|
| Blue black & white rock - hard | | 124 | 180 | 56 |
| Soft light green & white rock | | 180 | 185 | 5 |
| Blue Black & white hard | | 185 | 197 | 12 |
| Light green & white | | 197 | 246 | 49 |
| T.D. 246 feet | | | | |

8. WELL CONSTRUCTION

Diameter 6 inches Total depth 246 feet
 Casing record 5 inch O. D.
 Weight per foot 9.66 Thickness .188

| Diameter | From | To |
|-----------------|-----------------|-----------------|
| <u>5</u> inches | <u>106</u> feet | <u>246</u> feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |

Surface seal: Yes No Type _____
 Depth of seal _____ feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet

Perforations:
 Type perforation Factory
 Size perforation 3/32 X 3
 From 226 feet to 246 feet
 From _____ feet to _____ feet

Date started 6/12/90, 19____
 Date completed 6/14/90, 19____

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|-------------------------------------|--------|-----------|------------------|
| Blew with air to clean and develop. | | | |
| | | | |
| | | | |

BAILER TEST

| G.P.M. | Draw down | feet | hours |
|--------|-----------|------|-------|
| | | | |
| | | | |
| | | | |

9. WATER LEVEL

Static water level 80 feet below land surface
 Flow 20+ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc
 Address 625 Spice Islands Dr Suite L Sparks 89431
 Nevada contractor's license number issued by the State Contractor's Board 15291
 Nevada contractor's driller's number issued by the Division of Water Resources 1132
 Nevada driller's license number issued by the Division of Water Resources 1511
 Signed Roger M. Thrall
 Date Roger M. Thrall 6/22/90