WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 33828
Permit No.
Basin 8-101 Carson Desert

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 13138

1. OWNER Ed Van Den Broek
MAILING ADDRESS 5040 Hiatt Loop
Fallon Nv 89406

ADDRESS AT WELL LOCATION
5040 Hiatt Loop
Fallon Nv 89406

2. LOCATION N/W ¼ N/E ¼ Sec. 21 T. 18 N/S R. 28 E. Churchill County
PERMIT NO. Issued by Water Resources | 6-434-16 Parcel No. | Hiatt Loop Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fine Sand		0	10	10
clay		10	16	6
Coarse Sand		16	31	15
Green Coarse Sand		31	34	3
Black Sand		34	37	3
Green Sand		37	54	17
Brown Clay		54	57	3
Coarse Gravel	X	57	73	16
Clay		73	75	2

'90 JUL -5 A11:20 STATE ENGINEER'S OFFICE

See plugging report of old well log #

Date started June 27, 1990
Date completed June 30, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
3600	35	4.7	12

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12" inches Total depth 75 feet
..... inches
..... inches
Casing record ASTM-A-53-A
Weight per foot 12.92 Thickness .188

Diameter	From	To
6-5/8 inches	0 feet	75 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50" feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 75 feet

Perforations:
Type perforation Mill Cut
Size perforation 1/8"
From 65 feet to 75 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 8'8" feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name PARSONS DRILLING, INC. (Contractor)
Address 2054 Thomas Jeff. #130-10 Battle Mtn. Nev. (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada contractor's driller's number issued by the Division of Water Resources 1454
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1454-T1
Signed Douglas Parsons (By driller performing actual drilling on site or contractor)
Date June 30, 1990

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627