

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 14631

1. OWNER Ken Zeal ADDRESS AT WELL LOCATION 6855 Windy Hill Way  
MAILING ADDRESS 875 E Second St  
Reno, Nv 89502

2. LOCATION 5NW/4 35W/4 Sec. 36 T. 19 N/S R. 319E Washoe County  
PERMIT NO. 41-100-73 - Washoe Subdivision Name \_\_\_\_\_  
Issued by Water Resources Parcel No. \_\_\_\_\_

3. TYPE OF WORK  
New Well  Recondition   
Deepen  Other

4. PROPOSED USE  
Domestic  Irrigation  Test   
Municipal  Industrial  Stock

5. TYPE WELL  
Cable  Rotary   
Other  Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown gray black volcanic rock		0	42	42
Muti-colored volcanic rock		42	51	9
Black white w/some brown vol. rock [medium hard]		51	89	38
Multi-colored vol. rock w/traces yellow clay		89	97	8
Brown black white vol. rock [Med. hard]		97	132	35
Reddish brown vol. rock [med hard]		132	167	35
Red black white vol. rock [med. hard]		167	279	112
Gray & white vol. rock w/traces red volcanic rock [med hard]		279	335	56
Reddish brown vol. rock w/some black & green vol. rock [med. hard]		335	347	12
T.D. 347 feet				

8. 10" - 50" WELL CONSTRUCTION  
Diameter 8 1/2 inches Total depth 347 feet  
6 inches  
6 5/8 inches  
Casing record 6 5/8 and 5 inch  
Weight per foot 10.78 Thickness .156 & .188

Diameter	From	To
<u>6 5/8</u> inches	<u>+ 1</u> feet	<u>279</u> feet
<u>5</u> inches	<u>269</u> feet	<u>347</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type grout  
Depth of seal 51 feet  
Gravel packed: Yes  No   
Gravel packed from 51 feet to 279 feet

Perforations:  
Type perforation factory  
Size perforation 3/32 X 3  
From 239 feet to 279 feet  
From 307 feet to 327 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 7/17/90, 19\_\_\_\_\_  
Date completed 7/23/90, 19\_\_\_\_\_  
5  
2

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop.			

BAILER TEST

G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
Static water level 200 feet below land surface  
Flow 20+ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Aqua Drilling & Well Service, Inc  
Contractor  
Address 625 Spice Islands Dr Suite L Sparks 89431  
Contractor  
Nevada contractor's license number 15291  
issued by the State Contractor's Board  
Nevada contractor's driller's number 1132  
issued by the Division of Water Resources  
Nevada driller's license number issued by the 1509  
Division of Water Resources, the on-site driller  
Signed Roger M. Thrall  
By driller performing actual drilling on site or contractor  
Date 7/24/90