

OFFICE USE ONLY
 Log No. 33820e
 Permit No. _____
 Basin 6-91 Truckee Canyon seg.

PRINT OR TYPE ONLY

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 15578

1. OWNER Allen Flikkema ADDRESS AT WELL LOCATION 325 Riverdale Circle
 MAILING ADDRESS 1424 Frontier Lot 7 Block A
Reno, Nv 89503
 2. LOCATION 140W 1/4 3NW 1/4 Sec. 6 T. 19 N/S R. 18 E. Washoe County
 PERMIT NO. 38-693-01 - Riverdale # 1 Verdi
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown sandy soil		0	17	17
Lt brown sand clay & some brown rock		17	58	41
Dark green volcanic rock		58	210	152
Dark green volcanic rock [med hard]		210	312	102
Blue green brown volcanic rock with trace gray clay green volcanic rock		312	385	73
		385	396	11
T. D. 396 feet				

Deepened by STALLER log # 35836

8. 10" - 60' WELL CONSTRUCTION
 Diameter 8 1/2 inches Total depth 396 feet
 Casing record 6 5/8 inch
 Weight per foot 10.78 Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>+ 2</u> feet	<u>396</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type grout
 Depth of seal 54 feet
 Gravel packed: Yes No
 Gravel packed from 54 feet to 396 feet
 Perforations:
 Type perforation factory
 Size perforation 3/32 X 3
 From 356 feet to 376 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 6/28/90, 19____
 Date completed 6/29/90, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Blew with air to clean and develop.</u>			

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 250 feet below land surface
 Flow 20+ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc
Contractor
 Address 625 Spice Islands Dr Suite L Sparks 89431
Contractor
 Nevada contractor's license number 15291
 issued by the State Contractor's Board
 Nevada contractor's driller's number 1132
 issued by the Division of Water Resources
 Nevada driller's license number issued by the 1509
 Division of Water Resources, the on-site driller
 Signed Roger M. Thrall
By driller performing actual drilling on site or contractor
 Date Roger M. Thrall 7/2/90