WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

**Please complete this form in its entirety**

OFFICE USE ONLY
Log No. 33866
Permit No. 55021
Basin 4-72

NOTICE OF INTENT NO. 1262

PRINT OR TYPE ONLY

1. OWNER Frehner Constr.
MAILING ADDRESS 124 Brook ST
N Las Vegas

ADDRESS AT WELL LOCATION 1/4 mile South
Imlay, NV

2. LOCATION SE ¼ SE ¼ Sec. 8 T. 32 N S R. 34 E Pershing County
PERMIT NO. ~~240~~ Waiver C-110 Issued by Water Resources
Parcel No. N/A
Subdivision Name N/A

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☑ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Top Soil | | 0 | 2 | 2 |
| Sand + Gravel w/Boulders | | 2 | 34 | 32 |
| Sand | | 34 | 38 | 4 |
| Sand + Gravel w/Boulders | | 38 | 300 | |

Date started 7 11, 1990
Date completed 7 16, 1990

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | 350 | | |

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12¼ inches Total depth 300 feet
..... inches
..... inches
Casing record .....
Weight per foot ..... Thickness .....

| Diameter | From | To |
|---|---|---|
| 12¼ inches | 0 feet | 300 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☑ No ☐ Type Grout
Depth of seal 90 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 90 feet to 300 feet

Perforations:
Type perforation mill slot
Size perforation 12 rows 3/32
From 180 feet to 220 feet
From 240 feet to 282 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level No method to measure Depth at least 160' feet below land surface
Flow ~~350~~ G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson Contractor
Address 10760 Grass Valley Rd Contractor
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada contractor's driller's number issued by the Division of Water Resources 1375
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1375
Signed [signature] By driller performing actual drilling on site or contractor
Date 7-20-90

RECEIVED JUL 30 AM 11:27 STATE ENGINEER

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 11-85) (O)-627