WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

Also # 33735

OFFICE USE ONLY
Log No. 33869
Permit No. 52977
Basin 4-48 Terrill Creek Area

NOTICE OF INTENT NO. 12573

1. OWNER Stake Ranch
MAILING ADDRESS Lee-Jiggs
Elko, Nevada 89801

ADDRESS AT WELL LOCATION
Lee-Jiggs

2. LOCATION SE ¼ SE ¼ Sec. 13 T. 32 N/S R. 55 E. Elko County

PERMIT NO. 52977 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☒

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
clay		0	20	20
clay & sand		20	60	40
brown clay		60	80	20
white clay, sandstone		80	85	5
brown clay		85	100	15
tan clay		100	115	15
tan clay, sand		115	120	5
white & tan fractured rock		120	130	10
white & tan clay		130	140	10
tan & white clay, fractured rock		140	180	40
tan & brown clay		180	240	60
tan clay little sand		240	322	82

'90 JUN -1 A9:57 RECEIVED STATE ENGINEER'S OFFICE

Date started July 11, 1989
Date completed July 20, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 6-5/8 inches Total depth 322 feet
..... inches
..... inches
Casing record 6-5/8 inch
Weight per foot ..... Thickness .....

Diameter	From	To
inches	feet	feet
+2 inches	0 feet	322 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement grout
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 322 feet

Perforations:
Type perforation Mill slot
Size perforation .....
From ..... feet to ..... feet
From 172 feet to 322 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 120 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality .....

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Sargent Irrigation Company (Contractor)
Address P.O. Box 2646, Elko, Nevada 89801 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 21246
Nevada contractor's driller's number issued by the Division of Water Resources 1391
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1541
Signed [signature] (By driller performing actual drilling on site or contractor)
Date May 31, 1990

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627