

OFFICE USE ONLY
 Log No. 33725
 Permit No. 7-923
 Basin. Lemmon V.
 NOTICE OF INTENT NO. 14918

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

1. OWNER W.B. McDONALD ADDRESS AT WELL LOCATION 6510 Meyers
 MAILING ADDRESS 6460 S. Virginia Street Reno, NV 89511
 2. LOCATION SE 1/4 NE 1/4 Sec 16 T. 20N N/S R. 19 E Washoe County
 PERMIT NO. 82-660-17 Black Springs Subdivision Name
Issued by Water Resources Parcel No.

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other air

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|----------------------------|--------------|------|-----|------------|
| WELL DEEPENING: | | | | |
| Green granite | | 350 | 365 | 15 |
| Gray rilite w/clay streaks | | 365 | 373 | 8 |
| Green rilite | | 373 | 410 | 37 |
| Soft zone(app 3 GPM) | X | 410 | 414 | 4 |
| Green rilite | | 414 | 441 | 27 |
| Soft zone | X | 441 | 465 | 24 |
| Green rilite | | 465 | 516 | 51 |
| Fracture | X | 516 | 517 | 1 |
| Green rilite | | 517 | 545 | 28 |
| Soft zone | X | 545 | 560 | 15 |
| Green rilite | | 560 | 575 | 15 |

8. WELL CONSTRUCTION
 Diameter 5" OD inches Total depth 575 feet
 Casing record 575' steel liner installed.
 Weight per foot _____ Thickness .134

| Diameter | From | To |
|---------------------|---------------|-----------------|
| <u>5" OD</u> inches | <u>0</u> feet | <u>575</u> feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |

 Surface seal: Yes No Type N/A
 Depth of seal _____ feet
 Gravel packed: Yes No
 Gravel packed from 325 feet to 575 feet
 Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x .3 x 5 around
 From 325 feet to 345 feet
 From 405 feet to 465 feet
 From 505 feet to 525 feet
 From 545 feet to 565 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 290 feet below land surface
 Flow 75 G.P.M. P.S.I.
 Water temperature cold°F Quality XXXX clear

Date started 6-2-90 19____
 Date completed 6-6-90 19____

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|----------|--------|-----------|------------------|
| | | | |
| | | | |
| | | | |

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc. Contractor
 Address P.O. Box 12370, Reno, NV 89510 Contractor
 Nevada contractor's license number 22549 issued by the State Contractor's Board
 Nevada contractor's driller's number 908 issued by the Division of Water Resources
 Nevada driller's license number issued by the Division of Water Resources 923
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date June 6, 1990

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours