



WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 3890

PRINT OR TYPE ONLY

1. OWNER Stella A. Williams ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____

2. LOCATION SE 1/4 NE 1/4 Sec 28 T 19S N/S R. 53 E NYE County
 PERMIT NO. lot 10 Bell Vista Subdivision
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay		0'	16'	16'
caliche		16'	18'	2'
clay		18'	35'	17'
caliche		35'	37'	2'
clay		37'	43'	6'
caliche		43'	49'	6'
clay		49'	56'	7'
gravel		56'	60'	4'
clay		60'	79'	19'
caliche		79'	81'	2'
clay		81'	94'	13'
caliche	tr	94'	99'	5'
clay		99'	109'	10'
caliche	WB	109'	117'	8'
clay		117'	135'	18'
caliche	WB	135'	137'	2'
clay		137'	151'	14'
caliche	WB	151'	155'	4'
clay		155'	175'	20'
caliche	WB	175'	178'	3'
clay		178'	183'	5'
sand	WB	183'	186'	3'
clay		186'	200'	14'

8. WELL CONSTRUCTION
 Diameter 12 1/4 inches Total depth 200 feet
 _____ inches
 _____ inches
 Casing record 8 5/8" x 200'
 Weight per foot 14.11 Thickness .156

<u>8 5/8</u> Diameter	From	To
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type concrete
 Depth of seal 50' feet
 Gravel packed: Yes No
 Gravel packed from 200 feet to 50 feet
 Perforations:
 Type perforation factory sawcut
 Size perforation 1/8" x 3"
 From 200 feet to 140 feet
 From _____ feet to _____ feet

RECEIVED
 JUL 19 1990
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 7-9 1990
 Date completed 7-13 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 80 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name S. & H. Drilling Contractor
 Address HCR 65 box 80358 Pahrump, NV 89041 Contractor
 Nevada contractor's license number 22059
 issued by the State Contractor's Board
 Nevada contractor's driller's number 1426
 issued by the Division of Water Resources
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
 Signed Donna Brown
 By driller performing actual drilling on site or contractor
 Date 7-26-90