



WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8521

1. OWNER LARRY DONAGHY ADDRESS AT WELL LOCATION Alaska Way
Pahrump, NV
 MAILING ADDRESS P.O. Box 1970
Pahrump, NV

2. LOCATION SW 1/4 SW 1/4 Sec. 9 T 20S N/S R. 53 E NYE County
 PERMIT NO. N/A 17 Cal Vegas Ranchoes Unit D
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay		0'	12'	12'
caliche		12'	15'	3'
clay		15'	20'	5'
caliche		20'	23'	3'
clay		23'	41'	18'
caliche		41'	43'	2'
clay		43'	49'	6'
caliche		49'	50'	1'
clay		50'	59'	9'
caliche	WB	59'	64'	5'
clay		64'	71'	7'
caliche	WB	71'	74'	3'
clay		74'	80'	6'
caliche	WB	80'	82'	2'
clay		82'	89'	7'
caliche	WB	89'	96'	7'
clay		96'	108'	12'
caliche	WB	108'	112'	4'
clay		112'	120'	8'
caliche	WB	120'	124'	4'
clay		124'	130'	6'
caliche	WB	130'	135'	5'
clay		135'	140'	5'

Date started 7-26 19 90
 Date completed 8-3 19 90

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. Div. of Water Resources Draw down _____ feet _____ hours
 G.P.M. Branch Office - Las Vegas, NV Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

8. WELL CONSTRUCTION

Diameter 12 1/4 inches Total depth 140' feet
 _____ inches
 _____ inches

Casing record 140 x 8 5/8"
 Weight per foot 14.11 Thickness .156

Diameter	From	To
<u>8 5/8</u> inches	<u>0</u> feet	<u>140</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type concrete
 Depth of seal 50' feet
 Gravel packed: Yes No
 Gravel packed from 140 feet to 50' feet

Perforations:
 Type perforation 1 factory sawcut
 Size perforation 1/8" x 3"
 From 140 feet to 120 feet
 From _____ feet to _____ feet

9. WATER LEVEL

Static water level 43 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature Cool °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING
Contractor
 Address HCR 65 box 80358 Pahrump, NV 89041
Contractor

Nevada contractor's license number 30880
 issued by the State Contractor's Board

Nevada contractor's driller's number 1426
 issued by the Division of Water Resources

Nevada driller's license number issued by the 1573
 Division of Water Resources, the on-site driller

Signed Donnie Brown
 By driller performing actual drilling on site or contractor

Date 8-3-90

RECEIVED

AUG 08 1990