

8511

PRINT OR TYPE ONLY

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 8511

1. OWNER DICK CONSHAFTER ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION NE 1/4 SE 1/4 Sec. 20 T 20S N/S R. 53 E NYE County \_\_\_\_\_  
 PERMIT NO. \_\_\_\_\_ lot 2 block 421 Sunland Development Subdivision Name \_\_\_\_\_  
 Issued by Water Resources \_\_\_\_\_ Parcel No. \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Other   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
clay		0'	17'	17'
caliche		17'	19'	2'
clay		19'	26'	7'
caliche		26'	29'	3'
clay		29'	45'	16'
caliche		45'	47'	2'
clay		47'	56'	9'
caliche	WB	56'	61'	5'
clay		61'	72'	11'
caliche	WB	72'	74'	2'
clay		74'	88'	14'
caliche	WB	88'	91'	3'
clay		91'	98'	7'
caliche	WB	98'	103'	5'
clay		103'	110'	7'
caliche	WB	110'	115'	5'
clay		115'	123'	8'
caliche	WB	123'	126'	3'
clay		126'	130'	4'
caliche	WB	130'	134'	4'
clay		134'	140'	6'

8. WELL CONSTRUCTION  
 Diameter 12 1/4 inches Total depth 140 feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record 8 5/8" x 140'  
 Weight per foot 14.11 Thickness .156  
 Diameter From To  
8 5/8 inches \_\_\_\_\_ 0 feet \_\_\_\_\_ 140 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type concrete  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 140 feet to 50 feet  
 Perforations:  
 Type perforation factory sawcut  
 Size perforation 1 7/8" x 3"  
 From 140 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

**RECEIVED**  
**JUL 19 1990**

Div. of Water Resources  
 Branch Office Las Vegas, NV  
 Date started \_\_\_\_\_ 1990  
 Date completed 7-13 1990

9. WATER LEVEL  
 Static water level 46 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality \_\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name GREAT BASIN DRILLING Contractor  
 Address HCR 65 box 80358 Pahrump, NV 89041 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 30880  
 Nevada contractor's driller's number issued by the Division of Water Resources 1426  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573  
 Signed Dennis Brown  
 By driller performing actual drilling on site or contractor  
 Date 7-13-90

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours