

Log No. 34032  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

1. OWNER ROBERT BIVONA ADDRESS AT WELL LOCATION Carberry street  
 MAILING ADDRESS \_\_\_\_\_ Pahrump

2. LOCATION NE 1/4 SW 1/4 Sec. 2 T. 21s N/S R. 53 E NYE County  
 PERMIT NO. N/A Issued by Water Resources Lot 28 Parcel No. Rancho View Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay		0'	6'	6'
calichie		6'	9'	3'
clay		9'	23'	14'
calichie		23'	26'	3'
clay		26'	34'	8'
calichie		34'	36'	2'
clay		36'	58'	22'
calichie	WB	58'	62'	4'
clay		62'	77'	15'
calichie	WB	77'	79'	2'
clay		79'	90'	11'
calichie	WB	90'	95'	5'
clay		95'	112'	17'
calichie	WB	112'	116'	4'
clay		116'	124'	8'
calichie	WB	124'	128'	4'
clay		128'	136'	8'
calichie	WB	136'	140'	4'

RECEIVED  
 AUG 08 1990  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION  
 Diameter 12 1/2 inches Total depth 140' feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record 140' x 8 5/8"  
 Weight per foot 14.11 Thickness 15.6  
 Diameter From To  
8 5/8" inches \_\_\_\_\_ feet 140 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type concrete  
 Depth of seal 50' feet  
 Gravel packed: Yes  No   
 Gravel packed from 140 feet to 50 feet  
 Perforations:  
 Type perforation Factory sawcut  
 Size perforation 1/8" x 3"  
 From 140 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 7-23, 1990  
 Date completed 7-27, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 52 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cool °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name GREAT BASIN DRILLING Contractor  
 Address HCR 65 box 80358 Pahrump, NV 89041 Contractor  
 Nevada contractor's license number 30880  
 issued by the State Contractor's Board  
 Nevada contractor's driller's number 1426  
 issued by the Division of Water Resources  
 Nevada driller's license number issued by the 1573  
 Division of Water Resources, the on-site driller  
 Signed Home Brown  
 By driller performing actual drilling on site or contractor  
 Date 8-2-90