


OFFICE USE ONLY
 Log No. 34643
 Permit No. _____
 Basin 162



WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 8607

PRINT OR TYPE ONLY

1. OWNER Betty & Bob Springer ADDRESS AT WELL LOCATION Leslie & Irons
 MAILING ADDRESS _____
 2. LOCATION NE $\frac{1}{4}$ SE $\frac{1}{4}$ Sec. 11 T 21s N/S R. 53 E NYE County
 PERMIT NO. n/a 36-292-13 Lot 340 Unit F Calvegas Ranchoes
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay		0'	5'	5'
calichie		5'	9'	4'
clay		9'	20'	11'
calichie		20'	22'	2'
clay		22'	26'	4'
calichie		26'	34'	8'
clay		34'	44'	10'
calichie		44'	46'	2'
clay		46'	55'	9'
calichie	WB	55'	59'	4'
clay		59'	78'	19'
calichie	WB	78'	84'	6'
clay		84'	89'	5'
calichie	WB	89'	92'	3'
clay		92'	103'	11'
calichie	WB	103'	108'	5'
clay		108'	117'	9'
calichie	WB	117'	122'	5'
clay		122'	135'	13'
calichie	WB	135'	138'	3'
clay		138'	140'	2'

8. WELL CONSTRUCTION
 Diameter 12 1/2 inches Total depth 140' feet
 _____ inches
 _____ inches
 Casing record 140' x 8 5/8"
 Weight per foot 14.11 Thickness 156

Diameter	From	To
<u>8 5/8</u> inches	<u>0</u> feet	<u>140</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type concrete
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 140 feet to 50 feet
 Perforations:
 Type perforation factory sawcut
 Size perforation 1/8" x 3"
 From 140 feet to 120 feet
 From _____ feet to _____ feet

RECEIVED
 SEP 06 1990

Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 8-30 1990
 Date completed 9-4 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL
 Static water level 44 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name GREAT BASIN DRILLING
 Address HCR 65 box 80358 Pahrump, NV 89041
 Nevada contractor's license number issued by the State Contractor's Board 30880
 Nevada contractor's driller's number issued by the Division of Water Resources 1426
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller _____
 Signed James Brown
 By driller performing actual drilling on site or contractor
 Date 9-5-90

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours