

OFFICE USE ONLY
 Log No. 34048
 Permit No. _____
 Basin _____
 NOTICE OF INTENT NO. 7058

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

1. OWNER ROBERT HYBARGER ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____
 2. LOCATION SE 1/4 SE 1/4 Sec. 11 T. 21S N/S R. 53 E NYE County _____
 PERMIT NO. lot 4 Parcel No. _____ Subdivision Name Jocelyn Estates block 10

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay		0'	7'	7'
caliche		7'	8'	1'
clay		8'	24'	16'
caliche		24'	26'	2'
clay		26'	43'	17'
caliche		43'	44'	1'
clay		44'	56'	12'
caliche		56'	59'	3'
clay		59'	65'	6'
caliche	WB	65'	67'	2'
clay		67'	74'	7'
caliche	WB	74'	77'	3'
clay		77'	80'	3'
caliche	WB	80'	82'	2'
clay		82'	91'	9'
caliche	WB	92'	93'	2'
clay		93'	117'	24'
caliche	WB	117'	120'	3'
clay		120'	125'	5'
caliche	WB	125'	127'	2'
clay		127'	132'	5'
caliche	WB	132'	140'	8'

8. WELL CONSTRUCTION
 Diameter 12 1/2 inches Total depth 140 feet
 _____ inches
 _____ inches
 Casing record 8 5/8" x 140'
 Weight per foot 14.11 Thickness 1.56

Diameter	From	To
<u>8 5/8</u> inches	<u>0'</u> feet	<u>140'</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type concrete
 Depth of seal 50' feet
 Gravel packed: Yes No
 Gravel packed from 140' feet to 50' feet
 Perforations:
 Type perforation factory sawcut
 Size perforation 1/8" x 3"
 From 140' feet to 120' feet
 From _____ feet to _____ feet

Date started 6-25 1990
 Date completed 7-3 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 52 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature Cool °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name S&H Drilling Contractor
 Address HCR 65 box 80358 Pahrump, NV 89041 Contractor
 Nevada contractor's license number 22059 issued by the State Contractor's Board
 Nevada contractor's driller's number 1426 issued by the Division of Water Resources
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
 Signed Donna Brown
 By driller performing actual drilling on site or contractor
 Date 7-11-90