

OFFICE USE ONLY
 Log No. 34049
 Permit No. _____
 Basin _____
 NOTICE OF INTENT NO. 8516

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

1. OWNER CLINTON FITCH ADDRESS AT WELL LOCATION SWENDOLYN
 MAILING ADDRESS _____

2. LOCATION SE 1/4 SE 1/4 Sec 11 T 21s N/S R 53 E NYE County
 PERMIT NO. N/A Issued by Water Resources | 44-313-18 Parcel No. | Lot 17 Block 9 Jocelyn Estates Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay		0'	8'	8'
caliche		8'	9'	1'
clay		9'	22'	13'
caliche		22'	26'	4'
clay		26'	39'	13'
caliche		39'	41'	2'
clay		41'	61'	20'
caliche		61'	63'	2'
clay		63'	65'	2'
caliche	WB	65'	72'	7'
clay		72'	80'	8'
caliche	WB	80'	83'	3'
clay		83'	89'	6'
caliche	WB	89'	94'	5'
clay		94'	117'	23'
caliche	WB	117'	121'	4'
clay		121'	129'	8'
caliche	WB	129'	132'	3'
limestone		132'	136'	4'
clay		136'	140'	4'

8. WELL CONSTRUCTION
 Diameter 12 1/4 inches Total depth 140' feet
 Casing record 140' x 8 5/8"
 Weight per foot 14.11 Thickness 156

Diameter	From	To
<u>8 5/8</u> inches	<u>0</u> feet	<u>140'</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type concrete
 Depth of seal 50' feet
 Gravel packed: Yes No
 Gravel packed from 140 feet to 50 feet
 Perforations:
 Type perforation factory sawcut
 Size perforation 1/8" x 3"
 From 140 feet to 120 feet
 From _____ feet to _____ feet

RECEIVED

AUG 08 1990

Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 7-23 1990
 Date completed 7-27 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 54 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature Cool °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name GREAT BASIN DRILLING
 Address HCR 65 box 80358 Pahrump, NV 89041
 Nevada contractor's license number issued by the State Contractor's Board 30880
 Nevada contractor's driller's number issued by the Division of Water Resources 1426
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
 Signed Donna Brown
 By driller performing actual drilling on site or contractor
 Date 8-2-90