WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 34058
Permit No.
Basin

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8605

1. OWNER GREG JENTZ
MAILING ADDRESS PO Box 1181 Pahrump, NV

ADDRESS AT WELL LOCATION Bowler st.
Pahrump, NV

2. LOCATION NE ¼ SW ¼ Sec. 14 T. 21s N/S R. 53 E NYE County
PERMIT NO. n/a (Issued by Water Resources) | 44-733-07 (Parcel No.) | Mesa Oeste (Subdivision Name)

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☒ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☒ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
clay		0'	2'	2'
calichie		2'	3'	1'
clay		3'	12'	9'
calichie		12'	14'	2'
clay		14'	21'	7'
calichie		21'	23'	2'
clay		23'	39'	16'
calichie		39'	52'	13'
clay		52'	59'	7'
calichie	WB	59'	62'	3'
clay		62'	66'	4'
calichie	WB	66'	70'	4'
clay		70'	80'	10'
calichie	WB	80'	82'	2'
clay		82'	86'	4'
calichie	WB	86'	89'	3'
clay		89'	98'	9'
calichie	WB	98'	101'	3'
clay		101'	112'	11'
calichie	WB	112'	114'	2'
clay		114'	118'	4'
calichie	WB	118'	122'	4'
clay		122'	126'	4'
calichie	WB	126'	129'	3'
clay		129'	133'	4'
calichie	WB	133'	137'	4'
clay		137'	140'	3'

Date started 8-27, 1990
Date completed 8-30, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

RECEIVED
SEP 06 1990
Div. of Water Resources
Branch Office - Las Vegas, NV

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12¼ inches Total depth 140' feet
..... inches
..... inches
Casing record 140' x 8 5/8"
Weight per foot 14.11 Thickness .156

Diameter	From	To
8 5/8 inches	0 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type concrete
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 140 feet to 50 feet

Perforations:
Type perforation factory sawcut
Size perforation 1/8" x 3"
From 140 feet to 120 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 46 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature COOL °F Quality .....

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING (Contractor)
Address HCR 65 Box 80358 Pahrump, NV 89041 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada contractor's driller's number issued by the Division of Water Resources 1426
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 9-4-90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627