



PRINT OR TYPE ONLY

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 2493

1. OWNER Rod Conner ADDRESS AT WELL LOCATION Rancho Destino
 MAILING ADDRESS 3390 Wynn Rd. Ste-C
Las Vegas, Nv. 89102

2. LOCATION NE 1/4 SW 1/4 Sec. 16 T. 22 N/S R. 61 E Clark County
 PERMIT NO. Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|--|--------------|------|-----|------------|
| Aluvium | | 0 | 42 | 42 |
| Red clay | | 42 | 120 | 58 |
| Cemented Coglomerate | | 120 | 135 | 15 |
| Sandy red clay | | 135 | 182 | 47 |
| Cemented Conglomerate with streaks of red clay | | 182 | 400 | 218 |

8. WELL CONSTRUCTION

Diameter 10 inches Total depth 400 feet
 _____ inches
 _____ inches
 Casing record 6 5/8"
 Weight per foot 10.78 Thickness .156

| Diameter | From | To |
|-----------------|---------------|-----------------|
| <u>6</u> inches | <u>0</u> feet | <u>400</u> feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |

Surface seal: Yes No Type cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet

Perforations:
 Type perforation Torch
 Size perforation 1/8"x6"x4 around
 From 200 feet to 400 feet
 From _____ feet to _____ feet

Date started March 6 19 90
 Date completed March 10 19 90

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|------------|-----------|-----------|------------------|
| <u>air</u> | <u>50</u> | <u>?</u> | <u>1</u> |
| _____ | _____ | _____ | _____ |
| _____ | _____ | _____ | _____ |

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL

Static water level 157 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Allen Drilling, Inc. Contractor
 Address 4847 So. Valley View Contractor
 Nevada contractor's license number 0018917 issued by the State Contractor's Board
 Nevada contractor's driller's number 1301 issued by the Division of Water Resources
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1376
 Signed Allen B. Allen, Jr. By driller performing actual drilling on site or contractor
 Date _____