


Log No. 34161

Permit No. _____

Basin. 163



WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 5547

1. OWNER JIM WHITEHEAD ADDRESS AT WELL LOCATION 295 MANDAN ST
 MAILING ADDRESS Box 269 HCR 31 SANDY VALLEY
JEAN NEV. 89019

2. LOCATION SW 1/4 NW 1/4 Sec 5 T 25 N 57 E CLARK County
 PERMIT NO. 620450-005-90 Parcel No. NA Subdivision Name

Issued by Water Resources

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY LOAM		0	32	32
CALICHE		32	41	9
BROWN CLAY		41	48	7
CALICHE	WTR	48	51	3
WHITE CLAY		51	57	6
CORAL		57	69	12
GRAY CLAY		69	88	19
CALICHE	WTR	88	91	3
LTBROWN CLAY CON		91	102	11
CALICHE	WTR	102	110	8

8. WELL CONSTRUCTION

Diameter 14 inches Total depth 110 feet
 _____ inches
 _____ inches

Casing record 8 7/8 STEEL
 Weight per foot 12.5 Thickness 1.56

Diameter	From	To
<u>8 7/8</u> inches	<u>0</u> feet	<u>110</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type CEMENT
 Depth of seal 50 feet

Gravel packed: Yes No
 Gravel packed from 0 feet to 50 feet

Perforations:
 Type perforation FLAME CUT
 Size perforation 3/8 X 4
 From 90 feet to 110 feet
 From _____ feet to _____ feet

RECEIVED

JUN 15 1990

Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started MAY 10 1990
 Date completed JUNE 1 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>3450</u>	<u>25</u>	<u>3</u>	<u>2</u>
_____	_____	_____	_____
_____	_____	_____	_____

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL

Static water level 45 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature 68 °F Quality GOOD

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name R.C.B.B. Inc. Contractor
 Address 1701 W CHSN, LAS VEGAS NV 89102 Contractor

Nevada contractor's license number issued by the State Contractor's Board 020301

Nevada contractor's driller's number issued by the Division of Water Resources _____

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1352

Signed Robert Spurlock
 By driller performing actual drilling on site or contractor

Date June 13-90