

Log No. 34103

Permit No. _____

Basin. _____

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. _____

PRINT OR TYPE ONLY

1. OWNER CLARK COUNTY SANITATION DIST.

MAILING ADDRESS 5857 E. FLAMINGO ROAD
LAS VEGAS, NEVADA 89122

ADDRESS AT WELL LOCATION Same

2. LOCATION NW 1/4 NE 1/4 Sec. 15 T. 32 N/S.R. 66 E CLARK County

PERMIT NO. W 2034

Issued by Water Resources

Parcel No.

Subdivision Name

3. TYPE OF WORK	New Well <input checked="" type="checkbox"/>	Recondition <input type="checkbox"/>	4. PROPOSED USE	Domestic <input type="checkbox"/>	Irrigation <input type="checkbox"/>	5. TYPE WELL	Cable <input type="checkbox"/>	Rotary <input checked="" type="checkbox"/>
	Deepen <input type="checkbox"/>	Other <input type="checkbox"/>		Municipal <input type="checkbox"/>	Industrial <input type="checkbox"/>		Test <input checked="" type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG #1

8. WELL CONSTRUCTION

Diameter 6 1/2 inches Total depth 462 feet

Casing record _____

Weight per foot PVC Thickness SCH 80

Diameter	From	To
2 inches	457 feet	452 feet
2 inches	452 feet	432 feet
2 inches	432 feet	2FT ABOVE SURFACE
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type GROUT

Depth of seal BENTONITE TO 422/GROUT TO SURFACE

Gravel packed: Yes No

Gravel packed from 462 feet to 427 feet

Material	Water Strata	From	To	Thickness
SAND & GRAVEL		0	15	15
SILTY CLAY		15	30	15
SAND & GRAVEL		30	40	10
LAYERED ROCK SAND/GRAVEL		40	50	10
SAND & GRAVEL		50	55	5
GRAVEL W/CLAY		55	80	25
SILT/SAND/LAYERED ROCK		80	95	15
SAND/CLAY/ROCK		95	145	50
CLAY W/ SNAD SOME ROCK		145	175	30
" " "		175	185	10
CLAY		185	230	45
GRAVEL W/LAYERED CLAY		255	290	35
WEATHERED CONGLOMERATE		290	300	10
" " " "	X	300	430	130
FRACTURED CONGLOMERATE	X	430	462	32
(ALL COLORS)				

Perforations:

Type perforation PVC SCREEN

Size perforation .20

From 452 feet to 432 feet

From _____ feet to _____ feet

Date started AUG 23 10:36 AM MARCH 22, 1990

Date completed MAY 30 AM MARCH 25, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL

Static water level 371 feet below land surface

Flow Piezometer G.P.M. sewer P.S.I.

Water temperature 54 °F Quality ? water treat. plant

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name DAVE'S DRILLING COMPANY, INC.

Address 5617 W. WELLS PK. RD. WEST JORDAN, UT 8408

Nevada contractor's license number issued by the State Contractor's Board 0027289

Nevada contractor's driller's number issued by the Division of Water Resources _____

Nevada driller's license number issued by the Division of Water Resources the on-site driller 782/1990

Signed [Signature]
By driller performing actual drilling on site or contractor

Date 4/30/90

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours

G.P.M. _____ Draw down _____ feet _____ hours

G.P.M. _____ Draw down _____ feet _____ hours