WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 34113
Permit No.
Basin 9-106

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 14504

1. OWNER Edward Joseph
MAILING ADDRESS 444 s Main Street
Bishop, California

ADDRESS AT WELL LOCATION
2079 Comstock Drive
Gardnerville, Nevada 89410

2. LOCATION SE ¼ NW ¼ Sec. 32 T. 10 N/S R. 22 E. Douglas County
PERMIT NO. (Issued by Water Resources) 39-182-10 (Parcel No.) Topaz (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden with boulders		0	12	12
Alluvial material with boulders 1st water at 80 ft, major water course at 142-43 feet	x	12	150	138

Date started Aug. 21, 19 90
Date completed Aug. 24, 19 90

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Flushed mud from well and graveled well with pea gravel. Developed well after concrete seal was placed. Blew 30 gpm for 2 hours from 120 feet			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 11 3/4 inches Total depth 150 feet
8 3/4 inches
inches
Casing record 6 5/8"
Weight per foot 13.03 Thickness .188

Diameter	From	To
6 5/8 inches	42 feet	150 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Concrete
Depth of seal 106 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 106 feet to 150 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32" x 3"
From 130 feet to 150 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 78 feet below land surface
Flow 30 G.P.M. P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H PUMP CO. (Contractor)
Address CARSON CITY, NV 89701 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources 1535
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
Signed Jerald Pinnell (By driller performing actual drilling on site or contractor)
Date 3/26/90

SEP 07 1990 STATE ENGINEER'S OFFICE

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627