

OFFICE USE ONLY  
 Log No. 34123  
 Permit No. \_\_\_\_\_  
 Basin. 8-105

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 1429

1. OWNER John Rogals ADDRESS AT WELL LOCATION 735 Dignified Ct  
 MAILING ADDRESS 455 Dignified Ct Carsonville, NV 89410  
 2. LOCATION SW 1/4 SW 1/4 Sec 14 T 19 E Douglas County Carsonville, NV  
 PERMIT NO. 19-200-34 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name None

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand</u>		<u>0</u>	<u>16</u>	<u>16</u>
<u>Granite Boulder</u>		<u>16</u>	<u>32</u>	<u>16</u>
<u>Red Clay</u>		<u>32</u>	<u>46</u>	<u>14</u>
<u>P.C.</u>		<u>46</u>	<u>85</u>	<u>39</u>
<u>Fine-grained Granite</u>	<u>X</u>	<u>85</u>	<u>120</u>	<u>35</u>

'90 AUG -8 P 2:42  
 RECEIVED  
 STATE ENGINEERS OFFICE

Date started 6-28-90, 19\_\_\_\_  
 Date completed 6-29-90, 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Art Test 18</u>			

BAILER TEST

G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

8. WELL CONSTRUCTION

Diameter 10" 50' inches Total depth 120 feet  
8" 70' inches  
6 3/8 inches  
 Casing record 6 3/8  
 Weight per foot 12.5 Thickness 188

Diameter	From	To
<u>6</u> inches	<u>0</u>	<u>120</u> feet
_____ inches	_____	_____ feet
_____ inches	_____	_____ feet
_____ inches	_____	_____ feet
_____ inches	_____	_____ feet
_____ inches	_____	_____ feet

Surface seal: Yes  No  Type Factory  
 Depth of seal 50' feet  
 Gravel packed: Yes  No   
 Gravel packed from 50' feet to 120 feet

Perforations:  
 Type perforation Factory  
 Size perforation 3 x 3/32  
 From 100 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL

Static water level 28 feet below land surface  
 Flow 0 G.P.M. 0 P.S.I.  
 Water temperature 80 F Quality Unknown

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge

Name W.M. Blain Well Drilling Co., Inc. Contractor  
 Address 625 Fairview Suite 101 Contractor

Nevada contractor's license number issued by the State Contractor's Board 10950  
 Nevada contractor's driller's number issued by the Division of Water Resources 1118  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1652  
 Signed W.M. Blain By driller performing actual drilling on site or contractor  
 Date 08/05/90