

OFFICE USE ONLY
 Log No. 34130
 Permit No. _____
 Basin. B-105

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 74430

1. OWNER Michael Holsson ADDRESS AT WELL LOCATION 950 RIVERSIDE
 MAILING ADDRESS 950 RIVERSIDE CARONVILLE, NV 89410
 2. LOCATION SE 1/4 NE 1/4 Sec. 15 T. 12 N/S R. 20 E. Douglas County
 PERMIT NO. 27-741-11 Parcel No. CARONVILLE RANCHES Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Loess</u>		<u>0</u>	<u>86</u>	<u>86</u>
<u>Clay</u>		<u>86</u>	<u>92</u>	<u>6</u>
<u>Sand & gravel</u>		<u>92</u>	<u>114</u>	<u>22</u>
<u>Sand Clay</u>		<u>114</u>	<u>126</u>	<u>12</u>
<u>Gravel</u>	<input checked="" type="checkbox"/>	<u>126</u>	<u>168</u>	<u>42</u>
<u>Sticky Clay</u>		<u>168</u>	<u>176</u>	<u>8</u>
<u>Gravel</u>	<input checked="" type="checkbox"/>	<u>176</u>	<u>200</u>	<u>24</u>

1990 AUG -8 P 2:42
 RECEIVED
 STATE ENGINEERS OFFICE

Date started 6-14-90, 19.....
 Date completed 6-18-90, 19.....

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Antrot</u>	<u>15 gpm</u>		

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

8. WELL CONSTRUCTION
 Diameter 10 1/2 inches Total depth 200 feet
8 1/2 inches
 Casing record 6 5/8
 Weight per foot 12.5 Thickness 188

Diameter	From	To
<u>6</u> inches	<u>0</u> feet	<u>200</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type CONCRETE
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 200 feet
 Perforations:
 Type perforation Factory
 Size perforation 3/32
 From 160 feet to 180 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 42 feet below land surface
 Flow 0 G.P.M. _____ P.S.I.
 Water temperature 60 °F Quality UNKNOWN

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name W.M. Blankinship Drilling Co. NV Contractor
 Address 625 Fairview Suite 101 Reno Contractor
 Nevada contractor's license number issued by the State Contractor's Board 10950
 Nevada contractor's driller's number issued by the Division of Water Resources 1118
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1652
 Signed W.M. Blankinship
 By driller performing actual drilling on site or contractor
 Date 08/05/90