

OFFICE USE ONLY  
 Log No. 34131  
 Permit No. \_\_\_\_\_  
 Basin 8-105 Carson V.  
 14491

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. \_\_\_\_\_

1. OWNER BUCKEYE BUILDERS ADDRESS AT WELL LOCATION  
 MAILING ADDRESS P.O. Box 850 Off Genterville Lane 980 Rubio  
Minden, Nevada 89423 Gardnerville, Nevada

2. LOCATION SE 1/4 SE 1/4 Sec. 8 T 12 N/S R. 20 E Douglas County  
 PERMIT NO. None 27-070-30 None  
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Other  Mud

5. TYPE WELL  
 Cable  Rotary   
 Other  Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden with large cobbles		0	15	15
Gravel with fine to course sand and thin layers of clay		15	83	68
Hard, tight clay layer		83	86	3
Gravels carrying water, with fine to medium course sand	xxx	86	128	42

T.D. 128 ft

AUG 22 9:50 AM '90 STATE ENGINEER'S OFFICE

8. WELL CONSTRUCTION

Diameter 11 3/4 inches Total depth 128 feet

Casing record Steel

Weight per foot 11.7 Thickness .156

Diameter	From	To
<u>6 5/8"</u> inches	<u>2'</u> feet	<u>128</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type Concrete

Depth of seal 102 feet

Gravel packed: Yes  No

Gravel packed from 102 feet to 128 feet

Perforations:  
 Type perforation Factory Mill Slot  
 Size perforation 3/32" x 3"

From	To
<u>108</u> feet	<u>128</u> feet
_____ feet	_____ feet
_____ feet	_____ feet
_____ feet	_____ feet
_____ feet	_____ feet

Date started July 2, 1990  
 Date completed July 3, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Flushed well with clean water to gravel pack</u>			
<u>Developed well with 450 - 250 air. Blew</u>			
<u>25 plus gallons from 100 feet</u>			

BAILER TEST

G.P.M.	Draw down	feet	hours
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

9. WATER LEVEL

Static water level 48 feet below land surface

Flow 25 plus G.P.M. P.S.I. \_\_\_\_\_

Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A & H PUMP CO. Contractor

Address CARSON CITY, NEVADA 89701 Contractor

Nevada contractor's license number issued by the State Contractor's Board 23295

Nevada contractor's driller's number issued by the Division of Water Resources \_\_\_\_\_

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674

Signed Jay Britts By driller performing actual drilling on site or contractor

Date 7/3/90