WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 34134
Permit No.
Basin 3-1

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 15155

1. OWNER Dennis Murphy
MAILING ADDRESS PO Box 1106 Minden NV 89423
ADDRESS AT WELL LOCATION 1136 Linda Ann crt.

2. LOCATION NE ¼ NE ¼ Sec. 11 T. 12 N/S R. 20 E. Douglas County
PERMIT NO. (Issued by Water Resources) 23-211-06 (Parcel No.) Pinecrest (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & Clay		0	10	
Clay		10	55	
Gravel		55	60	
Clay & Sand	X	65	70	
Clay	X	70	90	
Rocks & Gravel	X	90	105	
Clay & Sand	X	105	110	
Rocks & Gravel	X	110	130	
Rocks & Gravel	XX	130	150	

'90 SEP 10 A11:21
RECEIVED
STATE ENGINEERS OFFICE

Date started 9-6, 1990
Date completed 9-9, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Air	20+		2hrs

'92 MAR 5 A11:29
RECEIVED
STATE ENGINEERS OFFICE

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 10 inches Total depth 150 feet
..... inches
..... inches
Casing record 1.05 thm A53
Weight per foot ..... Thickness .156

Diameter	From	To
6 inches	0 feet	150 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 150 feet

Perforations:
Type perforation Factory Rent
Size perforation 3" x 5/32"
From 130 feet to 150 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 56 feet below land surface
Flow 20+ G.P.M. ..... P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Rowchock Drilling Inc (Contractor)
Address 2668 Fulton Minden NV (Contractor)
Nevada contractor's license number issued by the State Contractor's Board #021268
Nevada contractor's driller's number issued by the Division of Water Resources #1380
Nevada driller's license number issued by the Division of Water Resources, the on-site driller #1495
Signed Michael Allen
By driller performing actual drilling on site or contractor
Date 9-10-90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627