

OFFICE USE ONLY
 Log No. 34157
 Permit No. _____
 Basin 8-105 Carson V.

WELL DRILLERS REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 7115

1. OWNER Walt Mahl ADDRESS AT WELL LOCATION 1651 Windmill Rd.
 MAILING ADDRESS Box 471 Gard. NU 89410

2. LOCATION $\frac{1}{4}$ $\frac{1}{4}$ Sec 33 T 13 N/S R. 21 E 7th Springs Douglas County
 PERMIT NO. _____ Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|-----------------------------|--------------|------|-----|------------|
| Clay | | 0 | 35 | |
| Clay (hard pan) | | 35 | 55 | |
| Clay & cobblestone | | 55 | 65 | |
| Clay | | 65 | 75 | |
| Clay & cobblestone & gravel | X | 75 | 90 | |
| Clay & gravel | X | 90 | 105 | |
| Clay & cobblestone & gravel | X | 105 | 120 | |
| Clay & gravel | XX | 120 | 140 | |

8. WELL CONSTRUCTION

Diameter hole 8 7/8 inches Total depth 140 feet
 Casing record _____
 Weight per foot _____ Thickness _____
 Diameter _____ inches From _____ feet To _____ feet
 _____ inches _____ feet _____ feet
 Surface seal: Yes No Type Concrete
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet
 Perforations:
 Type perforation Peter Robinsons
 Size perforation 3 x 5/16"
 From 123 feet to 140 feet
 From _____ feet to _____ feet

9. WATER LEVEL

Static water level 79 feet below land surface
 Flow 20+ G.P.M. _____ P.S.I.
 Water temperature Cold ° F. Quality Good

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Kowchack Drilling Co. Contractor
 Address 1578 Chiquita ch Minden NU 89423 Contractor
 Nevada contractor's license number 021268
 Nevada contractor's drillers number 1380
 Nevada driller's license number 1380
 Signed Ed J Kowchack Actual Driller
 Date 10/22/86 Contractor

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|----------|--------|-----------|------------------|
| | | | |
| | | | |
| | | | |

BAILER TEST
 G.P.M. 20+ Draw down 13 feet 1 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours